



**Generation Interconnection  
System Impact Study Report  
for**

**Queue Project AG1-124**

**GLADSTONE 138 KV**

**58.9 MW Capacity / 100 MW Energy**

November 2021

## Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General .....	5
4	Point of Interconnection.....	6
5	Cost Summary .....	6
6	Transmission Owner Scope of Work .....	8
6.1	Attachment Facilities.....	8
6.2	Direct Connection Cost Estimate.....	8
6.3	Non-Direct Connection Cost Estimate.....	8
7	Transmission Owner Analysis.....	9
8	Schedule.....	9
9	Interconnection Customer Requirements.....	9
10	Revenue Metering and SCADA Requirements .....	9
10.1	PJM Requirements .....	9
10.2	Meteorological Data Reporting Requirements .....	10
10.3	Interconnected Transmission Owner Requirements.....	10
11	Summer Peak Analysis .....	11
11.1	Generation Deliverability .....	11
11.2	Multiple Facility Contingency .....	11
11.3	Contribution to Previously Identified Overloads.....	11
11.4	Steady-State Voltage Requirements .....	12
11.5	Potential Congestion due to Local Energy Deliverability.....	12
11.6	System Reinforcements.....	14
11.7	Flow Gate Details.....	16
11.7.1	Index 1 .....	17
11.7.2	Index 2 .....	20
11.7.3	Index 3 .....	22
11.7.4	Index 4 .....	23
11.7.5	Index 5 .....	24
11.7.6	Index 6 .....	25
11.8	Queue Dependencies .....	27

11.9	Contingency Descriptions.....	29
12	Light Load Analysis.....	32
13	Short Circuit Analysis.....	32
14	Stability and Reactive Power .....	32
15	Affected Systems .....	33
15.1	TVA.....	33
15.2	Duke Energy Progress.....	33
15.3	MISO .....	33
15.4	LG&E.....	33
16	Attachment 1: One Line Diagram and Project Site Location.....	34

## 1 Introduction

This System Impact Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 205, as well as the System Impact Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is AEP.

## 2 Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

### 3 General

The Interconnection Customer (IC), has proposed a Solar generating facility located in Nelson County, Virginia. The installed facilities will have a total capability of 100 MW with 58.9 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is December 01, 2024. This study does not imply a TO commitment to this in-service date.

<b>Queue Number</b>	<b>AG1-124</b>
<b>Project Name</b>	GLADSTONE 138 KV
<b>State</b>	Virginia
<b>County</b>	Nelson
<b>Transmission Owner</b>	AEP
<b>MFO</b>	100
<b>MWE</b>	100
<b>MWC</b>	58.9
<b>Fuel</b>	Solar
<b>Basecase Study Year</b>	2024

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

## 4 Point of Interconnection

AG1-124 will interconnect with the AEP transmission system at the Gladstone 138 kV substation. The baseline project b3208 replaces the existing Gladstone 46 kV switch station to 138 kV substation.

To accommodate the interconnection to the Gladstone 138 kV substation, three (3) new 138 kV circuit breakers will be installed (see Attachment 1). Installation of associated protection and control equipment, 138 kV line risers, SCADA, and 138 kV revenue metering will also be required. AEP reserves the right to specify the final acceptable configuration considering design practices, future expansion, and compliance requirements.

Installation of the generator lead first span exiting the POI station, including the first structure outside the AEP fence, will also be included in AEP's scope. In the case where the generator lead is a single span, the structure in the customer station will be the customer's responsibility.

## 5 Cost Summary

The AG1-124 project will be responsible for the following costs:

Description	Total Cost
<b>Total Physical Interconnection Costs</b>	\$8,971,000
<b>Allocation towards System Network Upgrade Costs (PJM Identified - Summer Peak)*</b>	\$3,562,500
<b>Allocation towards System Network Upgrade Costs (PJM Identified - Light Load)*</b>	\$0
<b>Allocation towards System Network Upgrade Costs (TO Identified)*</b>	\$0
<b>Total Costs</b>	<b>\$12,533,000</b>

\*As your project progresses through the study process and other projects modify their request or withdraw, then your cost allocation could change.

The estimates provided in this report are preliminary in nature, as they were determined without the benefit of detailed engineering studies. Final estimates will require an on-site review and coordination to determine final construction requirements. In addition, Stability analysis will be completed during the Facilities Study stage. It is possible that a need for additional upgrades could be identified by these studies.

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 88-129. If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Note 1: PJM Open Access Transmission Tariff (OATT) section 217.3A outline cost allocation rules. The rules are further clarified in PJM Manual 14A Attachment B. The allocation of costs for a network upgrade will start with the first Queue project to cause the need for the upgrade. Later queue projects will receive cost allocation contingent on their contribution to the violation and are allocated to the queues that have not closed less than 5 years following the execution of the first Interconnection Service Agreement which identifies the need for this upgrade.

Note 2: For customers with System Reinforcements listed: If your present cost allocation to a System Reinforcement indicates \$0, then please be aware that as changes to the interconnection process occur, such as prior queued projects withdrawing from the queue, reducing in size, etc, the cost responsibilities can change and a cost allocation may be assigned to your project. In addition, although your present cost allocation to a System Reinforcement is presently \$0, your project may need this system reinforcement completed to be deliverable to the PJM system. If your project comes into service prior to completion of the system reinforcement, an interim deliverability study for your project will be required.

## 6 Transmission Owner Scope of Work

The total physical interconnection costs is given in the table below:

### 6.1 Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
138 kV Revenue Metering	\$376,000
Generator lead first span exiting the POI station, including the first structure outside the fence	\$400,000
<b>Total Attachment Facility Costs</b>	<b>\$776,000</b>

### 6.2 Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Three (3) new 138 kV circuit breakers will be installed at the Gladstone 138 kV substation. Installation of associated protection and control equipment, 138 kV line risers, and SCADA will also be required.	\$8,150,000
<b>Total Direct Connection Facility Costs</b>	<b>\$8,150,000</b>

### 6.3 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Review line protection and control settings at the Gladstone 138 kV substation	\$45,000
<b>Total Non-Direct Connection Facility Costs</b>	<b>\$45,000</b>



## 7 Transmission Owner Analysis

AEP did not find any sub-transmission overloads with the interconnection of AG1-124.

## 8 Schedule

It is anticipated that the time between receipt of executed Agreements and Commercial Operation may range from 12 to 18 months if no line work is required. If line work is required, construction time would generally be between 24 to 36 months after Agreement execution.

## 9 Interconnection Customer Requirements

It is understood that the Interconnection Customer (IC) is responsible for all costs associated with this interconnection. The costs above are reimbursable to the Transmission Owner. The cost of the IC's generating plant and the costs for the line connecting the generating plant to the Point of Interconnection are not included in this report; these are assumed to be the IC's responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for the Transmission Owner to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

## 10 Revenue Metering and SCADA Requirements

### 10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

## 10.2 Meteorological Data Reporting Requirements

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Back Panel temperature (Fahrenheit) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Irradiance (Watts/meter<sup>2</sup>) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Ambient air temperature (Fahrenheit) - (Accepted, not required)
- Wind speed (meters/second) - (Accepted, not required)
- Wind direction (decimal degrees from true north) - (Accepted, not required)

## 10.3 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/>

## 11 Summer Peak Analysis

The Queue Project AG1-124 was evaluated as a 100.0 MW (Capacity 58.90 MW) injection at the Gladstone 138 kV substation in the AEP area. Project AG1-124 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-124 was studied with a commercial probability of 100.0 %. Potential network impacts were as follows:

### 11.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
167837942	242549	05BANSTR	138.0	AEP	242632	05EDAN 2	138.0	AEP	1	AEP_P2-1_242720 05MONET A 138 242775 05ROCKCA S SS 138 1	single	296.0	99.84	101.18	AC	4.14

### 11.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
180629770	946590	AF1-323 TAP	138.0	AEP	242792	05SCOTSV	138.0	AEP	1	DVP_P4 -2: 547T566	breaker	167.0	98.06	105.26	AC	12.22
180694156	946590	AF1-323 TAP	138.0	AEP	242792	05SCOTSV	138.0	AEP	1	DVP_P4 -2: 56602	breaker	167.0	96.75	103.95	AC	12.22

### 11.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
181037254	242549	05BANSTR	138.0	AEP	242632	05EDAN 2	138.0	AEP	1	AEP_P2-1_242607 05CLOVRD 138 243892 05MEADS8 138 1	single	296.0	103.69	105.02	AC	4.14
185043607	938820	AE1-108 TAP	138.0	AEP	314746	4BREM O	138.0	DVP	1	DVP_P1-2: LN 566	single	157.0	101.98	106.46	AC	7.2
185118305	938820	AE1-108 TAP	138.0	AEP	314746	4BREM O	138.0	DVP	1	PJM_PLAN T BEAR GARDEN	single	157.0	101.94	106.02	AC	6.53

## 11.4 Steady-State Voltage Requirements

None

## 11.5 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC/D C	MW IMPAC T
1678379 41	24254 9	05BANSTR	138.0	AEP	24263 2	05EDAN 2	138.0	AEP	1	Base Case	operation	296.0	113.47	115.09	AC	5.94
1797826 09	24254 9	05BANSTR	138.0	AEP	24263 2	05EDAN 2	138.0	AEP	1	AEP_P2-1_242607 05CLOVRD 138 243892 05MEADS8 138 1	operation	296.0	147.45	149.41	AC	7.04
1678381 77	24255 0	05BEARSK	138.0	AEP	94008 0	AE1-250 TAP	138.0	AEP	1	AEP_P2-1_242607 05CLOVRD 138 243892 05MEADS8 138 1	operation	392.0	102.69	104.16	AC	7.04
1681074 39	24277 5	05ROCKCAS SS	138.0	AEP	24272 0	05MONE TA	138.0	AEP	1	AEP_P1-2_#5366_4 2-A	operation	409.0	101.03	102.15	AC	5.61
1681073 31	24280 2	05SMITHM TN	138.0	AEP	92605 0	AC1-083 TAP	138.0	AEP	1	AEP_P2-1_242607 05CLOVRD 138 243892 05MEADS8 138 1	operation	296.0	109.67	111.61	AC	7.04
1681073 73	24389 2	05MEADS8	138.0	AEP	24260 7	05CLOVR D	138.0	AEP	1	AEP_P1-2_#5366_4 2-A	operation	407.0	109.91	111.04	AC	5.61
1693431 21	31474 6	4BREMO	138.0	DVP	31474 4	3BREMO	115.0	DVP	1	Base Case	operation	186.1	115.42	121.22	AC	11.09
1746090 25	31474 6	4BREMO	138.0	DVP	31474 4	3BREMO	115.0	DVP	1	PJM_PLAN T BEAR GARDEN	operation	205.9	117.52	122.76	AC	11.09
1678379 68	92605 0	AC1-083 TAP	138.0	AEP	24255 0	05BEARSK	138.0	AEP	1	Base Case	operation	296.0	105.63	107.25	AC	5.94
1693430 10	93882 0	AE1-108 TAP	138.0	AEP	31474 6	4BREMO	138.0	DVP	1	Base Case	operation	157.0	137.64	144.62	AC	11.09
1840429 19	93882 0	AE1-108 TAP	138.0	AEP	31474 6	4BREMO	138.0	DVP	1	PJM_PLAN T BEAR GARDEN	operation	157.0	155.14	162.06	AC	11.09

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECTIONS LOADIN G %	POST PROJECTIONS LOADIN G %	AC/D C	MW IMPACT
169577649	940080	AE1-250 TAP	138.0	AEP	242549	05BANSTR	138.0	AEP	1	AEP_P2-1_24260705CLOVRD13824389205MEADS81381	operation	392.0	113.37	114.85	AC	7.04
169577651	940080	AE1-250 TAP	138.0	AEP	242549	05BANSTR	138.0	AEP	1	Base Case	operation	335.0	102.6	104.04	AC	5.94
180703858	946590	AF1-323 TAP	138.0	AEP	242792	05SCOTSV	138.0	AEP	1	DVP_P1-2:LN 566	operation	167.0	96.56	103.76	AC	12.22

## 11.6 System Reinforcements

ID	Idx	Facility	Upgrade Description	Cost	Cost Allocated to AG1-124	Upgrade Number												
181037254,167 837942	1	05BANSTR 138.0 kV - 05EDAN 2 138.0 kV Ckt 1	<p><u>AEP</u> <b>ProjectId : N5470 (AEPA0010e):</b> <b>Description :</b> A Sag Study will be required for the 10.7 miles of overhead conductor (2 bundle ACSR ~ 556.5 ~ 26/7 ~ DOVE) to mitigate the overload. Depending on the sag study results, the cost for this upgrade is expected to be between \$42,800 (no remediation required, just sag study) and \$21.4 million (complete line reconductor/rebuild). New Rating after sag study is SN 298 MVA, SE: 396 MVA. Time Estimate: a) Sag Study: 6-12 months b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement. <b>Type : FAC</b> <b>Total Cost : \$42,800</b> <b>Time Estimate : 6-12 Months</b> <b>Ratings : 298.0/396.0</b></p> <p><u>AEP</u> <b>ProjectId : n6457.1 (AEPA0010a):</b> <b>Description :</b> Rebuild / reconductor 196 ft. of overhead conductor (ACSR ~ 1033.5 ~ 45/7 ~ ORTOLAN) <b>Type : FAC</b> <b>Total Cost : \$55,500</b> <b>Time Estimate : 24-36 Months</b> <b>Ratings : 335.0/392.0</b></p> <p>These constraints are driven by a prior queue. Per PJM cost allocation rules, Queue Project AG1-124 presently does not receive cost allocation for this upgrade.</p>	\$64,200 + \$55,500	\$0 + \$0	n5470 n6457.1												
185043607,185 118305	2	AE1-108 TAP 138.0 kV - 4BREMO 138.0 kV Ckt 1	<p><u>DVP</u> <b>ProjectId : n7812 (dom-397):</b> <b>Description :</b> Upgrade Description: Reconductor 8.502 miles of 138 kV line 8 from AE1-108 Tap to Brema with 636 ACSR 150 C <b>Type : FAC</b> <b>Total Cost : \$5,101,200</b> <b>Time Estimate : 30-36 Months</b> <b>Ratings : 261.0/261.0/301.0</b></p> <table><tr><th>Queue</th><th>MW</th><th>Cost %</th><th>Cost \$</th></tr><tr><td>AG1-123</td><td>3.17</td><td>30.56%</td><td>\$1,558,700</td></tr><tr><td>AG1-124</td><td>7.2</td><td>69.44%</td><td>\$3,542,500</td></tr></table>	Queue	MW	Cost %	Cost \$	AG1-123	3.17	30.56%	\$1,558,700	AG1-124	7.2	69.44%	\$3,542,500	\$5,101,200	\$3,542,500	n7812
Queue	MW	Cost %	Cost \$															
AG1-123	3.17	30.56%	\$1,558,700															
AG1-124	7.2	69.44%	\$3,542,500															

ID	Idx	Facility	Upgrade Description	Cost	Cost Allocated to AG1-124	Upgrade Number
180629770,180694156	6	AF1-323 TAP 138.0 kV - 05SCOTSV 138.0 kV Ckt 1	<p><u>AEP</u>  <b>ProjectId : n7811 (AEPA0034a):</b>  <b>Description :</b> Description: A sag study will be required on the 0.85 miles of ACSR ~ 397.5 ~ 30/7 ~ LARK - Conductor to determine what mitigation would be required (if any) to operate at the conductor's MOT. Depending on the sag study results, the cost for this upgrade is expected to be between \$3,400 (no remediation required, just sag study) and \$1.275 million (complete line reconductor/rebuild). Time Estimate: a) Sag Study: 6-12 months b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement  <b>Type : FAC</b>  <b>Total Cost : \$20,000</b>  <b>Time Estimate : 6-12 Months</b>  <b>Ratings : 167.0/235.0</b></p> <p>This project is the driver for the overload.</p>	\$20,000	\$20,000	n7811
			<b>TOTAL COST</b>	<b>\$5,240,900</b>	<b>\$3,562,500</b>	

Note : For customers with System Reinforcements listed: If your present cost allocation to a System Reinforcement indicates \$0, then please be aware that as changes to the interconnection process occur, such as prior queued projects withdrawing from the queue, reducing in size, etc, the cost responsibilities can change and a cost allocation may be assigned to your project. In addition, although your present cost allocation to a System Reinforcement is presently \$0, your project may need this system reinforcement completed to be deliverable to the PJM system. If your project comes into service prior to completion of the system reinforcement, an interim deliverability study for your project will be required.

## 11.7 Flow Gate Details

The following indices contain additional information about each facility presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. The intent of the indices is to provide more details on which projects/generators have contributions to the flowgate in question. All New Service Queue Requests, through the end of the Queue under study, that are contributors to a flowgate will be listed in the indices. Please note that there may be contributors that are subsequently queued after the queue under study that are not listed in the indices. Although this information is not used "as is" for cost allocation purposes, it can be used to gage the impact of other projects/generators. It should be noted the project/generator MW contributions presented in the body of the report are Full MW Impact contributions which are also noted in the indices column named "Full MW Impact", whereas the loading percentages reported in the body of the report, take into consideration the PJM Generator Deliverability Test rules such as commercial probability of each project as well as the ramping impact of "Adder" contributions. The MW Impact found and used in the analysis is shown in the indices column named "Gendeliv MW Impact".

---



### 11.7.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
181037254	242549	05BANSTR	AEP	242632	05EDAN 2	AEP	1	AEP_P2-1_242607 05CLOVRD 138 243892 05MEADS8 138 1	single	296.0	103.69	105.02	AC	4.14

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
242889	05REUSENS	0.05	80 50	0.05
246843	05SMG1	3.72	80 50	3.72
246844	05SMG2	10.1	80 50	10.1
246845	05SMG3	6.33	80 50	6.33
246846	05SMG4	9.94	80 50	9.94
246847	05SMG5	3.87	80 50	3.87
247284	05LEESVG	2.02	80 50	2.02
315156	1HALLBR1	1.34	80 50	1.34
316123	AC1-075 C	0.48	80 50	0.48
925661	AC1-042 C	2.72	80 50	2.72
926023	AC1-080 C	0.16	80 50	0.16
926051	AC1-083 C O1	19.1	80 50	19.1
926521	AC1-123 C O1	2.1	80 50	2.1
926645	AC1-145 C	0.53	80 50	0.53
933941	AD1-017 C	3.82	80 50	3.82
935241	AD1-161 C	2.6	80 50	2.6
938451	AE1-064 C	21.46	80 50	21.46
939011	AE1-130 C	17.63	80 50	17.63
939941	AE1-230 C	1.23	80 50	1.23
940081	AE1-250 C	57.52	80 50	57.52
941801	AE2-185 C	6.14	80 50	6.14
941821	AE2-187 C	6.14	80 50	6.14
942671	AE2-283 C	6.75	80 50	6.75
942751	AE2-291 C	6.12	80 50	6.12
942761	AE2-292 C O1	7.62	80 50	7.62
945081	AF1-173	2.38	80 50	2.38
958131	AF2-107 C	1.89	80 50	1.89
961121	AF2-403	1.36	80 50	1.36
962741	AG1-123 C O1	3.1	80 50	3.1
962751	AG1-124 C O1	4.14	80 50	4.14
963601	AG1-209 C	0.48	80 50	0.48
964531	AG1-316 C O1	4.73	80 50	4.73
966251	AG1-494 C	1.37	80 50	1.37
966691	AG1-539 C	3.2	80 50	3.2
966761	AG1-547 C	5.55	80 50	5.55
LTFEXP_AC1-056	LTFEXP_AC1-056->LTFIMP_AC1-056	0.2308	Confirmed LTF	0.2308
LTFEXP_AC1-131	LTFEXP_AC1-131->LTFIMP_AC1-131	2.0551	Confirmed LTF	2.0551

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LTFEXP_BlueG	LTFEXP_BlueG->LTFIMP_BlueG	0.1949	Confirmed LTF	0.1949
LTFEXP_CALDERWOOD	LTFEXP_CALDERWOOD->LTFIMP_CALDERWOOD	0.3627	Confirmed LTF	0.3627
LTFEXP_CATAWBA	LTFEXP_CATAWBA->LTFIMP_CATAWBA	0.5712	Confirmed LTF	0.5712
LTFEXP_CHEOAH	LTFEXP_CHEOAH->LTFIMP_CHEOAH	0.3802	Confirmed LTF	0.3802
LTFEXP_COTTONWOOD	LTFEXP_COTTONWOOD->LTFIMP_COTTONWOOD	1.2354	Confirmed LTF	1.2354
LTFEXP_GIBSON	LTFEXP_GIBSON->LTFIMP_GIBSON	0.0812	Confirmed LTF	0.0812
LTFEXP_HAMLET	LTFEXP_HAMLET->LTFIMP_HAMLET	1.1965	Confirmed LTF	1.1965
LTFEXP_NY	LTFEXP_NY->LTFIMP_NY	0.0548	Confirmed LTF	0.0548
LTFEXP_PRAIRIE	LTFEXP_PRAIRIE->LTFIMP_PRAIRIE	0.7796	Confirmed LTF	0.7796
LTFEXP_TRIMBLE	LTFEXP_TRIMBLE->LTFIMP_TRIMBLE	0.0586	Confirmed LTF	0.0586
242889	05REUSSENS	0.05	80 50	0.05
246843	05SMG1	3.72	80 50	3.72
246844	05SMG2	10.1	80 50	10.1
246845	05SMG3	6.33	80 50	6.33
246846	05SMG4	9.94	80 50	9.94
246847	05SMG5	3.87	80 50	3.87
247284	05LEESVG	2.02	80 50	2.02
315156	1HALLBR1	1.34	80 50	1.34
316123	AC1-075 C	0.48	80 50	0.48
925661	AC1-042 C	2.72	80 50	2.72
926023	AC1-080 C	0.16	80 50	0.16
926051	AC1-083 C O1	19.1	80 50	19.1
926521	AC1-123 C O1	2.1	80 50	2.1
926645	AC1-145 C	0.53	80 50	0.53
933941	AD1-017 C	3.82	80 50	3.82
935241	AD1-161 C	2.6	80 50	2.6
938451	AE1-064 C	21.46	80 50	21.46
939011	AE1-130 C	17.63	80 50	17.63
939941	AE1-230 C	1.23	80 50	1.23
940081	AE1-250 C	57.52	80 50	57.52
941801	AE2-185 C	6.14	80 50	6.14
941821	AE2-187 C	6.14	80 50	6.14
942671	AE2-283 C	6.75	80 50	6.75
942751	AE2-291 C	6.12	80 50	6.12
942761	AE2-292 C O1	7.62	80 50	7.62
945081	AF1-173	2.38	80 50	2.38
958131	AF2-107 C	1.89	80 50	1.89
961121	AF2-403	1.36	80 50	1.36
962741	AG1-123 C O1	3.1	80 50	3.1
962751	AG1-124 C O1	4.14	80 50	4.14
963601	AG1-209 C	0.48	80 50	0.48
964531	AG1-316 C O1	4.73	80 50	4.73
966251	AG1-494 C	1.37	80 50	1.37
966691	AG1-539 C	3.2	80 50	3.2

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
966761	AG1-547 C	5.55	80 50	5.55
LTFEXP_AC1-056	LTFEXP_AC1-056->LTFIMP_AC1-056	0.2308	Confirmed LTF	0.2308
LTFEXP_AC1-131	LTFEXP_AC1-131->LTFIMP_AC1-131	2.0551	Confirmed LTF	2.0551
LTFEXP_BlueG	LTFEXP_BlueG->LTFIMP_BlueG	0.1949	Confirmed LTF	0.1949
LTFEXP_CALDERWOOD	LTFEXP_CALDERWOOD->LTFIMP_CALDERWOOD	0.3627	Confirmed LTF	0.3627
LTFEXP_CATAWBA	LTFEXP_CATAWBA->LTFIMP_CATAWBA	0.5712	Confirmed LTF	0.5712
LTFEXP_CHEOAH	LTFEXP_CHEOAH->LTFIMP_CHEOAH	0.3802	Confirmed LTF	0.3802
LTFEXP_COTTONWOOD	LTFEXP_COTTONWOOD->LTFIMP_COTTONWOOD	1.2354	Confirmed LTF	1.2354
LTFEXP_GIBSON	LTFEXP_GIBSON->LTFIMP_GIBSON	0.0812	Confirmed LTF	0.0812
LTFEXP_HAMLET	LTFEXP_HAMLET->LTFIMP_HAMLET	1.1965	Confirmed LTF	1.1965
LTFEXP_NY	LTFEXP_NY->LTFIMP_NY	0.0548	Confirmed LTF	0.0548
LTFEXP_PRAIRIE	LTFEXP_PRAIRIE->LTFIMP_PRAIRIE	0.7796	Confirmed LTF	0.7796
LTFEXP_TRIMBLE	LTFEXP_TRIMBLE->LTFIMP_TRIMBLE	0.0586	Confirmed LTF	0.0586

## 11.7.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
185118305	938820	AE1-108 TAP	AEP	314746	4BREMO	DVP	1	PJM_PLANT BEAR GARDEN	single	157.0	101.94	106.02	AC	6.53

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
242889	05REUSENS	0.05	80 50	0.05
935241	AD1-161 C	1.94	80 50	1.94
938821	AE1-108 C O1	61.69	80 50	61.69
946591	AF1-323 C	20.17	80 50	20.17
958131	AF2-107 C	8.94	80 50	8.94
960111	AF2-302 C	7.33	80 50	7.33
961801	AG1-022 C	7.33	80 50	7.33
962741	AG1-123 C O1	5.27	80 50	5.27
962751	AG1-124 C O1	6.53	80 50	6.53
964531	AG1-316 C O1	3.53	80 50	3.53
965581	AG1-426	11.69	80 50	11.69
966251	AG1-494 C	3.18	80 50	3.18
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.0504	Confirmed LTF	0.0504
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	0.2101	LTF/CBM	0.2101
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	3.4433	LTF/CBM	3.4433
LTFEXP_CBM-W1	LTFEXP_CBM-W1->LTFIMP_CBM-W1	6.881	LTF/CBM	6.881
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	4.7451	LTF/CBM	4.7451
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	0.0722	Confirmed LTF	0.0722
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	0.9211	Confirmed LTF	0.9211
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.0201	Confirmed LTF	0.0201
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	0.3491	Confirmed LTF	0.3491
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	0.826	Confirmed LTF	0.826
LTFEXP_NY	LTFEXP_NY->LTFIMP_NY	0.1194	Confirmed LTF	0.1194
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.0571	Confirmed LTF	0.0571
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	0.7731	Confirmed LTF	0.7731
LTFEXP_WEC	LTFEXP_WEC->LTFIMP_WEC	0.1611	Confirmed LTF	0.1611
242889	05REUSENS	0.05	80 50	0.05
935241	AD1-161 C	1.94	80 50	1.94
938821	AE1-108 C O1	61.69	80 50	61.69
946591	AF1-323 C	20.17	80 50	20.17

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
958131	AF2-107 C	8.94	80 50	8.94
960111	AF2-302 C	7.33	80 50	7.33
961801	AG1-022 C	7.33	80 50	7.33
962741	AG1-123 C O1	5.27	80 50	5.27
962751	AG1-124 C O1	6.53	80 50	6.53
964531	AG1-316 C O1	3.53	80 50	3.53
965581	AG1-426	11.69	80 50	11.69
966251	AG1-494 C	3.18	80 50	3.18
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.0504	Confirmed LTF	0.0504
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	0.2101	LTF/CBM	0.2101
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	3.4433	LTF/CBM	3.4433
LTFEXP_CBM-W1	LTFEXP_CBM-W1->LTFIMP_CBM-W1	6.881	LTF/CBM	6.881
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	4.7451	LTF/CBM	4.7451
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	0.0722	Confirmed LTF	0.0722
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	0.9211	Confirmed LTF	0.9211
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.0201	Confirmed LTF	0.0201
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	0.3491	Confirmed LTF	0.3491
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	0.826	Confirmed LTF	0.826
LTFEXP_NY	LTFEXP_NY->LTFIMP_NY	0.1194	Confirmed LTF	0.1194
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.0571	Confirmed LTF	0.0571
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	0.7731	Confirmed LTF	0.7731
LTFEXP_WEC	LTFEXP_WEC->LTFIMP_WEC	0.1611	Confirmed LTF	0.1611

### 11.7.3 Index 3

None

#### 11.7.4 Index 4

None

#### 11.7.5 Index 5

None



## 11.7.6 Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
180629770	946590	AF1-323 TAP	AEP	242792	05SCOTSV	AEP	1	DVP_P4-2: 547T566	breaker	167.0	98.06	105.26	AC	12.22

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
925661	AC1-042 C	0.68	Adder	0.8
925662	AC1-042 E	1.12	Adder	1.32
926522	AC1-123 E O1	1.14	Adder	1.34
926646	AC1-145 E	0.73	Adder	0.86
935241	AD1-161 C	1.96	Adder	2.31
935242	AD1-161 E	1.61	Adder	1.89
939941	AE1-230 C	0.31	Adder	0.36
939942	AE1-230 E	0.55	Adder	0.65
941801	AE2-185 C	1.54	Adder	1.81
941802	AE2-185 E	1.03	Adder	1.21
941821	AE2-187 C	1.54	Adder	1.81
941822	AE2-187 E	0.69	Adder	0.81
942671	AE2-283 C	1.7	Adder	2.0
942672	AE2-283 E	0.89	Adder	1.05
945081	AF1-173	0.6	Adder	0.71
946293	AF1-293 BAT	8.38	80 50	8.38
946591	AF1-323 C	20.19	80 50	20.19
946592	AF1-323 E	13.46	80 50	13.46
958131	AF2-107 C	9.19	80 50	9.19
958132	AF2-107 E	5.04	80 50	5.04
960111	AF2-302 C	7.34	80 50	7.34
960112	AF2-302 E	4.9	80 50	4.9
961063	AF2-397 BAT	2.88	Adder	3.39
961121	AF2-403	0.34	Adder	0.4
961801	AG1-022 C	7.34	80 50	7.34
961802	AG1-022 E	4.9	80 50	4.9
962741	AG1-123 C O1	5.76	80 50	5.76
962742	AG1-123 E O1	4.01	80 50	4.01
962751	AG1-124 C O1	7.2	80 50	7.2
962752	AG1-124 E O1	5.02	80 50	5.02
963601	AG1-209 C	0.12	Adder	0.14
963602	AG1-209 E	0.18	Adder	0.21
964531	AG1-316 C O1	3.57	Adder	4.2
964532	AG1-316 E O1	1.3	Adder	1.53
965582	AG1-426 BAT	6.26	80 50	6.26
966251	AG1-494 C	3.38	80 50	3.38
966252	AG1-494 E	5.07	80 50	5.07
966761	AG1-547 C	1.39	Adder	1.64
966762	AG1-547 E	0.75	Adder	0.88
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.1845	Confirmed LTF	0.1845

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	0.4114	LTF/CBM	0.4114
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	8.0009	LTF/CBM	8.0009
LTFEXP_CBM-W1	LTFEXP_CBM-W1->LTFIMP_CBM-W1	12.9404	LTF/CBM	12.9404
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	9.2206	LTF/CBM	9.2206
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	0.272	Confirmed LTF	0.272
LTFEXP_G-007	LTFEXP_G-007->LTFIMP_G-007	0.5652	LTF/CMTX NF	0.5652
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	1.8195	Confirmed LTF	1.8195
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.0477	Confirmed LTF	0.0477
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	0.6602	Confirmed LTF	0.6602
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	1.5751	Confirmed LTF	1.5751
LTFEXP_NY	LTFEXP_NY->LTFIMP_NY	0.2367	Confirmed LTF	0.2367
LTFEXP_O-066	LTFEXP_O-066->LTFIMP_O-066	3.5833	LTF/CMTX NF	3.5833
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.1083	Confirmed LTF	0.1083
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	1.5254	Confirmed LTF	1.5254
LTFEXP_WEC	LTFEXP_WEC->LTFIMP_WEC	0.3041	Confirmed LTF	0.3041

## 11.8 Queue Dependencies

The Queue Projects below are listed in one or more indices for the overloads identified in your report. These projects contribute to the loading of the overloaded facilities identified in your report. The percent overload of a facility and cost allocation you may have towards a particular reinforcement could vary depending on the action of these earlier projects. The status of each project at the time of the analysis is presented in the table. This list may change as earlier projects withdraw or modify their requests.

Queue Number	Project Name	Status
AA2-074	CPL-PJM	Confirmed
AC1-042	Altavista-Mt. Airy 69kV	Engineering and Procurement
AC1-056	PJM-AMIL	Confirmed
AC1-075	Perth-Hickory Grove 115kV	Partially in Service - Under Construction
AC1-080	Perth-Hickory Grove 115kV	Under Construction
AC1-083	Smith Mountain-Bearskin 138kV	Under Construction
AC1-123	Smith Mountain-Candler's Mountain 138kV	In Service
AC1-131	PJM-CPL	Confirmed
AC1-145	Gretna DP 69 kV	Under Construction
AD1-017	Smith Mountain-Bearskin 138 kV	Under Construction
AD1-161	Stonewall-Long Mountain 69 kV	Active
AE1-064	Rockcastle 138 kV	Active
AE1-108	Bremo-Scottsville 138 kV	Active
AE1-130	Meads Store 138 kV	Active
AE1-230	Shockoe 69 kV	Active
AE1-250	Smith Mountain-E. Danville 138 kV	Active
AE2-092	Kidds Store-Sherwood 115 kV	Active
AE2-185	Gladys DP-Stonemill Switching Station 69 kV	Active
AE2-187	Shockoe DP-Chatham 69 kV	Active
AE2-283	Gladys-Stone Mill 69 kV	Active
AE2-291	Grit DP-Perth 115 kV	Active
AE2-292	Grit DP-Perth 115 kV	Active
AF1-173	Gretna DP-Shockoe DP 69 kV	Active
AF1-293	Kidds Store-Fort Union 115 kV	Active
AF1-323	Scottsville-Colleen 138 kV	Active
AF2-107	Clifford 138 kV	Active
AF2-302	Scottsville-Colleen 138 kV	Active
AF2-397	Fork Union-Mt. Eagle 230 kV	Active
AF2-403	Shockoe DP-Chatham 69 kV	Active
AG1-022	Scottsville-Colleen 138 kV	Active
AG1-123	Amherst-Riverville 138 kV	Active
AG1-124	Gladstone 138 kV	Active
AG1-209	Gretna 12.5 kV	Active
AG1-284	Fork Union 115 kV	Active
AG1-316	Sherwill 69 kV	Active
AG1-426	Bremo-Scottsville 138 kV	Active
AG1-494	Boxwood-Riverville 138 kV	Active
AG1-539	Grit DP-Perth 115 kV	Active
AG1-547	Mount Airy-Chatham 69 kV	Active



## 11.9 Contingency Descriptions

Contingency Name	Contingency Definition
<b>DVP_P1-2: LN 566</b>	CONTINGENCY 'DVP_P1-2: LN 566' OPEN BRANCH FROM BUS 242519 TO BUS 314912 CKT 1 /* 05CLOVRD 500.00 - 8LEXNGTN 500.00 END
<b>AEP_P2-1_242549 05BANSTR 138 940080 AE1-250 TAP 138 1-A</b>	CONTINGENCY 'AEP_P2-1_242549 05BANSTR 138 940080 AE1-250 TAP 138 1-A' OPEN BRANCH FROM BUS 242549 TO BUS 940080 CKT 1 END
<b>AEP_P1-2_#10336-B</b>	CONTINGENCY 'AEP_P1-2_#10336-B' OPEN BRANCH FROM BUS 938820 TO BUS 314746 CKT 1 / 938820 AE1-108 TAP 138 314746 4BREMO 138 1 END
<b>DVP_P1-2: LN 8-B</b>	CONTINGENCY 'DVP_P1-2: LN 8-B' OPEN BRANCH FROM BUS 938820 TO BUS 314746 CKT 1 /* AE1-108 TAP 138.00 - 4BREMO 138.00 OPEN BRANCH FROM BUS 314744 TO BUS 314746 CKT 1 /* 3BREMO 115.00 - 4BREMO 138.00 OPEN BUS 314746 /* ISLAND: 4BREMO 138.00 END
<b>DVP_P1-2: LN 2193</b>	CONTINGENCY 'DVP_P1-2: LN 2193' OPEN BRANCH FROM BUS 313707 TO BUS 313867 CKT 1 /* 6FORK UNION 230.00 - 6BREMODIST 230.00 OPEN BRANCH FROM BUS 313867 TO BUS 314747 CKT 1 /* 6BREMODIST 230.00 - 6BREMO 230.00 OPEN BUS 313867 /* ISLAND: 6BREMODIST 230.00 END
<b>AEP_P2-1_242720 05MONETA 138 242775 05ROCKCAS SS 138 1</b>	CONTINGENCY 'AEP_P2-1_242720 05MONETA 138 242775 05ROCKCAS SS 138 1' OPEN BRANCH FROM BUS 242720 TO BUS 242775 CKT 1 END
<b>AEP_P4_#15269_05RIVERV 138_CB5</b>	CONTINGENCY 'AEP_P4_#15269_05RIVERV 138_CB5' OPEN BRANCH FROM BUS 242688 TO BUS 242772 CKT 1 / 242688 05JOSHUA 138 242772 05RIVERV 138 1 REMOVE LOAD C3 FROM BUS 242772 / 242772 05RIVERV 138 C3 END

Contingency Name	Contingency Definition
<b>PJM_PLANT BEAR GARDEN</b>	CONTINGENCY 'PJM_PLANT BEAR GARDEN' REMOVE MACHINE G1 FROM BUS 315191 REMOVE MACHINE G2 FROM BUS 315192 REMOVE MACHINE S1 FROM BUS 315193 END
<b>AEP_P1-2_#5366_42-A</b>	CONTINGENCY 'AEP_P1-2_#5366_42-A' OPEN BRANCH FROM BUS 242549 TO BUS 940080 CKT 1 / 242549 05BANSTR 138 940080 AE1-250 TAP 138 1 OPEN BRANCH FROM BUS 242549 TO BUS 242632 CKT 1 / 242549 05BANSTR 138 242632 05EDAN 2 138 1 OPEN BRANCH FROM BUS 242549 TO BUS 314668 CKT Z1 / 242549 05BANSTR 138 314668 4BANISTR 138 Z1 END
<b>DVP_P4-2: 56602</b>	CONTINGENCY 'DVP_P4-2: 56602' /* LEXINGTON 500 KV OPEN BRANCH FROM BUS 242519 TO BUS 314912 CKT 1 /* 05CLOVRD 500.00 - 8LEXNGTN 500.00 OPEN BRANCH FROM BUS 314856 TO BUS 314912 CKT 1 /* 6LEXNGT2 230.00 - 8LEXNGTN 500.00 END
<b>AEP_P4_#10164_05EDAN 2 138_M</b>	CONTINGENCY 'AEP_P4_#10164_05EDAN 2 138_M' OPEN BRANCH FROM BUS 242531 TO BUS 304094 CKT 1 / 242531 05EDANV2 230 304094 6YANCY TAP 230 1 OPEN BRANCH FROM BUS 242531 TO BUS 242632 CKT 4 / 242531 05EDANV2 230 242632 05EDAN 2 138 4 OPEN BRANCH FROM BUS 242549 TO BUS 940080 CKT 1 / 242549 05BANSTR 138 940080 AE1-250 TAP 138 1 OPEN BRANCH FROM BUS 242549 TO BUS 242632 CKT 1 / 242549 05BANSTR 138 242632 05EDAN 2 138 1 OPEN BRANCH FROM BUS 242549 TO BUS 314668 CKT Z1 / 242549 05BANSTR 138 314668 4BANISTR 138 Z1 / OPEN BRANCH FROM BUS 242550 TO BUS 242802 CKT 1 / 242550 05BEARSK 138 242802 05SMITHMTN 138 1 / OPEN BRANCH FROM BUS 242550 TO BUS 314671 CKT Z1 / 242550 05BEARSK 138 314671 4BEARSKN 138 Z1 OPEN BRANCH FROM BUS 242629 TO BUS 242632 CKT 1 / 242629 05E.MONU 138 242632 05EDAN 2 138 1 OPEN BRANCH FROM BUS 242631 TO BUS 242632 CKT Z1 / 242631 05EDAN 1 138 242632 05EDAN 2 138 Z1 END
<b>Base Case</b>	

Contingency Name	Contingency Definition
<b>DVP_P4-2: 547T566</b>	CONTINGENCY 'DVP_P4-2: 547T566' /* LEXINGTON 500 KV OPEN BRANCH FROM BUS 314901 TO BUS 314912 CKT 1 /* 8BATH CO 500.00 - 8LEXNGTN 500.00 OPEN BRANCH FROM BUS 242519 TO BUS 314912 CKT 1 /* 05CLOVRD 500.00 - 8LEXNGTN 500.00 END
<b>AEP_P2-1_242607 05CLOVRD 138 243892 05MEADS8 138 1</b>	CONTINGENCY 'AEP_P2-1_242607 05CLOVRD 138 243892 05MEADS8 138 1' OPEN BRANCH FROM BUS 242607 TO BUS 243892 CKT 1 END

## **12 Light Load Analysis**

Not applicable.

## **13 Short Circuit Analysis**

The following Breakers are overdutied:

None.

## **14 Stability and Reactive Power**

(Summary of the VAR requirements based upon the results of the dynamic studies)

To be determined in the Facilities Study Phase.



## **15 Affected Systems**

### **15.1 TVA**

None

### **15.2 Duke Energy Progress**

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

### **15.3 MISO**

MISO Impacts to be determined during later study phases (as applicable).

### **15.4 LG&E**

None

16 Attachment 1: One Line Diagram and Project Site Location



