



Generation Interconnection
Combined Feasibility/System Impact Study Report
for
Queue Project AG1-330
BEAVERTOWN 12.47 KV
4.5 MW Capacity / 5 MW Energy

January 2021

Table of Contents

1	Introduction.....	3
2	Preface.....	3
3	General	4
4	Point of Interconnection.....	4
5	Cost Summary	4
6	Transmission Owner Scope of Work	5
6.1	Attachment Facilities.....	5
6.2	Direct Connection Cost Estimate.....	5
6.3	Non-Direct Connection Cost Estimate.....	5
7	Schedule.....	6
8	Interconnection Customer Requirements.....	6
8.1	Voltage Rise Control.....	6
8.2	Transformer Winding	6
8.3	Intertie Protective Relaying Equipment.....	6
8.4	Other Requirements	7
9	Revenue Metering and SCADA Requirements.....	7
9.1	PJM Requirements	7
9.2	Meteorological Data Reporting Requirements	8
9.3	Interconnected Transmission Owner Requirements.....	8
10	Summer Peak - Load Flow Analysis	9
10.1	Generation Deliverability	9
10.2	Multiple Facility Contingency	9
10.3	Contribution to Previously Identified Overloads.....	9
10.4	Potential Congestion due to Local Energy Deliverability.....	9
10.5	System Reinforcements - Summer Peak Load Flow - Primary POI.....	10
11	Short Circuit Analysis.....	10
11.1	System Reinforcements - Short Circuit.....	10
12	Affected Systems	10
13	Attachment 1: One Line Diagram	11

1 Introduction

This Combined Feasibility/Impact Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is PPL.

2 Preface

The intent of the combined Feasibility/Impact study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC), **ASD Brick Plant PA2 Solar LLC**, has proposed a Solar - Storage hybrid generating facility located in Beaver County, Pennsylvania. The facility consists of 5 MW solar generation coupled with 4.5 MW (9 MWH) battery storage. The installed facilities will have a total capability limited to 5 MW with 4.5 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is July 31, 2022. This study does not imply a TO commitment to this in-service date.

Queue Number	AG1-330
Project Name	BEAVERTOWN 12.47 KV
State	Pennsylvania
County	Beaver
Transmission Owner	PPL
MFO	5
MWE	5
MWC	4.5
Fuel	Solar; Battery Storage
Basecase Study Year	2024

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

4 Point of Interconnection

AG1-330 will interconnect with the PPL EU Distribution system via Beavertown 12.47 kV circuit 43-02, 2.50 miles from the Beavertown 69/12 kV Substation Bus. The Point of Interconnection (POI) will be where the PPL EU's 12 kV terminates, prior to the customer's transformer/switchgear.

5 Cost Summary

The AG1-330 project will be responsible for the following costs:

Description	Total Cost
Total Physical Interconnection Costs	\$2,091,600
Total System Network Upgrade Costs	\$0
Total Costs	\$2,091,600

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 88-129. If at a future date it is determined

that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

6 Transmission Owner Scope of Work

Since this project is non-Ferc jurisdictional, the scope, cost and schedule will be covered in a two party interconnection agreement between the transmission owner and the interconnection customer. A preliminary estimate is provided below:

PPL EU can accommodate this 5MW generator and two 2.25 MW battery storage systems interconnection by upgrading the Beavertown 69/12 kV substation and installing line devices on the Beavertown 43-02 line. AG1-330 is located on the Beavertown 43-02 12kV line in the vicinity of 40.7464880, -77.1832590.

The total preliminary cost estimate for the Attachment Facility work is given in the table below. These costs do not include CIAC Tax Gross-up.

6.1 Attachment Facilities

Description	Total Cost
12 kV point of contact recloser	\$ 102,000
12kV line extension to point of interconnection	\$ 5,000
Total Attachment Facility Costs	\$ 107,000

6.2 Direct Connection Cost Estimate

None.

6.3 Non-Direct Connection Cost Estimate

The following non-direct facilities will be required:

- 12kV line protective device
- Reconductor 0.57 miles to 477 AL and convert to 3-phase (due to voltage rise/flicker)
- Extend substation yard and fence at Beavertown 69/12 kV substation
- Remove existing 69 kV structure
- Install a 69 kV circuit switcher and foundation at Beavertown 69/12 kV substation
- Install 69 kV Potential Transformers (PTs) at Beavertown 69/12 kV substation
- Install 69 kV 3-phase Current Transformers (CTs) at Beavertown 69/12 kV substation
- Install 12 kV line PT relay in a box (RIAB) with sync check relay on 43-02 circuit breaker at Beavertown 69/12 kV substation
- Install VIP SCADA system at Beavertown 69/12 kV substation.

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
12kV line protective device	\$102,000
0.57 miles of line reconductoring	\$568,600
Extend substation yard and fence	\$ 462,000
Remove existing 69 kV structure	\$ 240,000
69 kV Circuit switcher, foundation and testing	\$ 300,000
2 x 69 kV Potential Transformers (PTs)	\$ 60,000
2 x 69 kV 3-phase Current Transformers (CTs)	\$ 60,000
12 kV line PT and relay in a box (RIAB) with sync check on 43-02 circuit breaker	\$ 120,000
VIP SCADA System	\$ 72,000
Total Non-Direct Connection Facility Costs	\$ 1,984,000

7 Schedule

The estimated time to complete the scope of work is 18-24 months after the Interconnection Agreement (IA) is signed and PPL EU receives Notice to Proceed from the IC.

8 Interconnection Customer Requirements

8.1 Voltage Rise Control

In order to ensure that the voltage rise at the point of interconnection does not exceed 2.5%, the Interconnection Customer will be required to operate at a power factor of 98% lagging (absorbing VARs) at all times. If customers served from Beavertown substation begin to experience unacceptable voltage fluctuation due to the customer's operations, the customer will be disconnected by PPL EU System Operations and will be required to cease operations and construct reinforcements necessary to mitigate the problem at their expense before being re-energized. Power factor will be monitored via SCADA to ensure this operational requirement is met and maintained. Deviation from this power factor at any time will result in being disconnected from the PPL EU Distribution system.

8.2 Transformer Winding

The customer's transformer windings shall be "WYE" to "WYE" with a solidly grounded high side transformer winding.

8.3 Intertie Protective Relaying Equipment

The customer will have to install an Intertie Protective Relaying (IPR) scheme at their facility for their 5,000-kW solar generator. The customer should refer to the PPL EU web site for the IPR requirements. PPL EU's

preference for IPR is the SEL-751 relay package. Note that failure of the single microprocessor-based relay will disable the protection. For that reason, PPL EU requests that a backup relay be installed. Suitable choices for backup are the SEL 351-1 or SEL-751 packages. Note that the SEL-751-A is not allowed. The alternative would be to disconnect the generation in the event that the single relay is out of service. The website addresses are noted below:

<https://www.pplelectric.com/-/media/PPLElectric/At-Your-Service/Docs/transmission-services/parallel-generation-requirements-distribution12kVandbelow.pdf?la=en>
Point-of-Contact (POC) Recloser

PPL Relay Test personnel will require a written commissioning procedure proposed by the IPP's contractor. This procedure should cover a step-by-step listing of the tests required to ensure that the IPP's schemes operate properly. This commissioning procedure should be supplied to PPL EU at least two weeks prior to the scheduled in-service testing process. The generator shall provide a detailed procedure of the initial phase-out and synchronization to PPL EU, which must be reviewed and approved by PPL EU prior to actual synchronization. Additional details on the customer point of contact requirements can be found on PPL's Point of Contact Requirements for Distribution Voltage Customer-Owned Facilities document:

<https://www.pplelectric.com/-/media/PPLElectric/At-Your-Service/Docs/point-of-contact-requirements-12kV.pdf?la=en>

A point of contact recloser, to be provided by PPL EU and paid for by the customer, will be required at the customer's point of interconnection. Additional details on the customer point of contact requirements can be found on PPL EU's Point of Contact Requirements for Distribution Voltage Customer-Owned Facilities document, linked above.

8.4 Other Requirements

If PPL EU needs to operate the system in an abnormal configuration so that the customer is served by a different line, the customer may be asked to turn off their generation while abnormally configured. PPL EU also reserves the right to change the normal source to the customer as required by system conditions.

In addition, information about requirements for a 12.47 kV service can be found at PPL EU's Rules for Electric Meter and Service Installations website:

<https://www.pplelectric.com/at-your-service/electric-rates-and-rules/remsi.aspx>

9 Revenue Metering and SCADA Requirements

9.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

9.2 Meteorological Data Reporting Requirements

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

9.3 Interconnected Transmission Owner Requirements

Installation of revenue grade Bi-directional Metering Equipment will be required in the vicinity of the POI to measure kWh and kVARh. PPL EU will design and supply the required metering equipment; all installation costs would be borne by the IC including CTs/PTs. All metering equipment must meet applicable PPL EU tariff requirements as well as being compliant with all applicable requirements of the PJM agreements. The equipment must provide bidirectional revenue metering (kWh and kVARh) and real-time data (kW, kVAR, circuit breaker status, and generator bus voltages) for the IC's generating resource. The metering equipment should be housed in a control cabinet or similar enclosure and must be accessible to PPL EU metering personnel.

PPL EU also requires that the customer install SCADA at the common generator bus to provide PPL EU with real time operation parameters, including, but not limited to amps, voltage, MW, MVAR, power factor, etc. The SCADA system shall meet PPL EU SCADA standards and will primarily be for monitoring purposes but will provide PPL EU the ability to remotely disconnect the solar generation in emergency conditions. Additional details on the SCADA requirements for generators connecting to the PPL EU distribution system can be found in PPL EU's Relay and Control Requirements for Parallel Operation of Distributed Generation, which may be found on the PPL EU website or at the following link:

<https://www.pplelectric.com/-/media/PPLElectric/At-Your-Service/Docs/transmission-services/parallelgeneration-requirements-distribution12kVandbelow.pdf?la=en>

10 Summer Peak - Load Flow Analysis

The Queue Project AG1-330 was evaluated as a 5 MW (Capacity 4.5 MW) injection at the Beavertown 12.47 kV substation in the PPL area. Project AG1-330 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-330 was studied with a commercial probability of 100.0 %. Potential network impacts were as follows:

10.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

10.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

10.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

10.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

10.5 System Reinforcements - Summer Peak Load Flow - Primary POI

None

11 Short Circuit Analysis

The following Breakers are overdutied:

None

11.1 System Reinforcements - Short Circuit

None

12 Affected Systems

None

13 Attachment 1: One Line Diagram

