

***PJM Generator Interconnection Request***  
***Queue #R49***  
***Haviland-Milan(Ohio West Wind) 138kV***  
***Impact Study***  
**(Revised per R Queue Retool and Horizon Choice of Option to Build the  
Interconnection Station)**

539216  
June 2009  
V2 August 2010

## **R49 Haviland-Milan 138kV Impact Study Report**

### **General**

Horizon Wind Energy, LLC (Horizon) proposes to install a 150 MW generating facility comprised of 83-1.8 MW wind turbine generators connecting to the American Electric Power (AEP) Haviland - Milan 138 kV circuit. This project is number R49 in the PJM Generator Interconnection queue. The proposed location of the generating facilities and switching station is approximately four miles south of Payne, OH (See Exhibit 1). The projected in-service date is scheduled for June 1, 2011 for 99MW and October 31, 2011 for 50.4MW.

### **Attachment Facilities**

The proposed generation project will be connected to the AEP Haviland - Milan 138 kV circuit via a new in-line switching station. The new station will consist of three (3) 138 kV circuit breakers configured in a ring-bus arrangement with 138 kV metering (See Exhibit 2). AEP will retain ownership of the proposed in-line station facilities. In addition, remote terminal relaying will need to be upgraded to coordinate with the new relays to be installed at the new station. It is understood that Horizon will be responsible for the all costs associated with this construction, as well as facilities associated with connecting their 150 MW generation to the in-line facilities.

It is expected that any right-of-way for line extensions, as well as a 250' x 250' (minimum) station site will be provided to AEP by Horizon. Note that the Horizon station facilities and any facilities outside the new station were not included in the cost estimate. These are assumed to be Horizon's responsibility.

The AEP construction scope includes:

Horizon Wind Energy, LLC has chosen the “Option to Build” for the R49 interconnection station.

- Provide inspection and oversight services for the new switching station connecting to the Haviland - Milan 138 kV circuit between Haviland and Tillman stations, including three (3) 138 kV circuit breakers, relays, 138 kV metering, SCADA, and associated equipment. (Network Upgrade #n1222)

PJM estimated cost: \$400,000

- Replace line relaying with AEP standard package and upgrade the station remote terminal unit (RTU) at Milan station. (Network Upgrade #n1223)

Estimated Cost (2009 Dollars): **\$682,500**

- Replace line relaying with AEP standard package and upgrade the station remote terminal unit (RTU) at Haviland station. (Network Upgrade #n1224)

Estimated Cost (2009 Dollars): **\$721,000**

- Replace line relaying with AEP standard package and upgrade the station remote terminal unit (RTU) at Tillman station. (Network Upgrade #n1225)

Estimated Cost (2009 Dollars): **\$370,100**

- Cut-in and terminate the Haviland-Tillman 138kV circuit in the new interconnection station for the R49 project. (Network Upgrade #n2041)

Estimated Cost: \$600,000

Total Attachment Facilities Cost\*: **\$2,773,600**

\*The estimates are preliminary in nature, as they were determined without the benefit of detailed engineering studies. Final estimates will require an on-site review and coordination to determine final construction requirements. It will take approximately fourteen (14) to eighteen (18) months after obtaining an executed ISA and CSA to construct the facilities as outlined above.

## **Local Impacts**

The impact of the proposed generating facility on the AEP System was assessed for adherence with applicable reliability criteria. AEP planning criteria require that the transmission system meet single contingency performance criteria in accordance with the AEP FERC Form 715. Therefore, this criterion was used to assess the impact of the proposed facility on the AEP System. The Horizon project was studied as a 150 MW net capacity consistent with the interconnection application. The results are summarized below.

### Normal System (2009 Summer Conditions)

- No problems identified.

### Single Contingency (2009 Summer Conditions)

- Outage of the Haviland - R49 Ohio West 138 kV circuit overloads the Tillman 138/34.5 kV transformer to 101% of its summer rating.

### Short Circuit Analysis

- No problems identified.

## Stability Analysis

- Instability occurs for an outage of the Robison Park - R49 and East Lima – Haviland 138 kV lines (double-contingency scenario). In this scenario, both 138 kV outlets are outaged, and R49 is connected only to the underlying 69 kV network via the Haviland 138/69 kV Station. **Generation curtailment will be required following the first contingency (loss of either the Robison Park – R49 or East Lima – Haviland 138 kV circuit).**

## Local Upgrades

To maintain appropriate levels of reliability and mitigate the single contingency problems resulting from the additional generation identified in this study, the following system improvements are required:

- To alleviate the overload on the Tillman 138/34.5kV transformer the existing transformer will be replaced with a 30 MVA unit that will require installation of a high-side circuit switcher and associated equipment. (Network Upgrade #n1226)

Estimated Cost (2009 Dollars): **\$1,856,600\***

\*The estimates are preliminary in nature, as they were determined without the benefit of detailed engineering studies. Final estimates will require an on-site review and coordination to determine final construction requirements. It will take approximately one year after obtaining the authorization to construct the facilities as outlined above.

## Reactive Requirements

PJM requires a power factor correction to 95 lead-0.99 lag at the point of interconnection for wind generating facilities. It is expected that Horizon will adhere to this standard.

## Network Impacts

The Queue Project #R49 was studied as a(n) 150 MW(Capacity=30 MW) injection into the Haviland – Milan 138 kV line in the AEP area. Project #R49 was evaluated for compliance with reliability criteria for summer peak conditions in 2012. Potential network impacts were as follows:

## Generator Deliverability

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

No problems were identified

## Multiple Facility Contingency

*(Double Circuit Tower Line, Line with Failed Breaker and Bus Fault contingencies for the full energy output)*

No problems were identified

### **Short Circuit**

No problems identified

### **Re-Tool Result**

The retool analysis has shown that two 138kV circuit breakers at East Lima are overdutied due to the installation of the R49 project. The results are summarized in the table below.

| BUS_NO | BUS             | BREAKER | Rating Type | Duty Percent With r049 | Duty Percent Without r049 | Duty Percent Difference | Note          |
|--------|-----------------|---------|-------------|------------------------|---------------------------|-------------------------|---------------|
| 0      | 05E LIMA 138.kV | E2      | T           | 100.70%                | 99.70%                    | 1.00%                   | New Over duty |
| 0      | 05E LIMA 138.kV | C       | T           | 100.30%                | 99.40%                    | 0.90%                   | New Over duty |

### **Stability and Reactive Power Requirement** **Background**

This study concerns the stability assessment for the PJM generator interconnection request – Queue #R49 (Havilland-Milan 138 kV Tap). The R49 project consists on a new 150 MW wind farm facility. The developer specified the use of 72 units Suzlon 2.1 MW wound rotor induction generator.

The objective of the study was to determine the system stability for the contingencies around the R49 project as shown in Attachment #1.

All units and its control systems were updated according to the developer's specification; these updates are shown in Attachment #2 and Attachment #3 (Dynamic data format).

The topology of the system is shown in Attachment #4

### **Stability (AEP Stability Criteria)**

Stability analysis was performed at 2013 summer peak load condition. The maximum generation output is considered. The range of contingencies evaluated was limited to that necessary to assess expected compliance with AEP criteria.

This study includes 74 contingencies conditions that includes 3-phase permanent fault with unsuccessful High-Speed-Recloser (HSR) for normal clearing time contingencies and single line to ground for delayed clearing time due to stuck breaker condition and line tripping without fault.

## **Result and Analysis**

No stability problem was identified with the new transmission line upgrade. The swing angles do not exceed the transient stability criteria and the transient voltage and low voltage ride through criteria were also satisfactory for all contingencies scenarios.

Table-1 in Attachment #1 tabulates the clearing times for the all contingencies scenarios, also a brief description of the scenario is provided.

Whenever R49 wind farm plant is islanded with a load, we recommend the following values for trip settings at the interconnection point:

Voltage at the point of interconnection:

0.8 pu or lower for 2 seconds

1.11 pu or higher for 0.1 second

1.2 pu or higher for 0.02 second

Frequency at the point of interconnection:

57Hz or lower for 0.05 seconds

62Hz or higher for 0.05 second

Note: While the stability analysis has been performed at expected extreme system conditions, there is a potential that evaluation at a different level of generator MW and/or MVAR output at different system load levels and operating conditions would disclose unforeseen stability problems. The regional reliability analysis routinely performed to test all system changes will include one such evaluation. Any problems uncovered in that or other operating or planning studies will need to be resolved.

Moreover, when the proposed generating station is designed and plant specific dynamics data for the plant and its controls are available, and if it is different than the data provided for this study, a transient stability analysis at a variety of expected operating conditions using the more accurate data shall be performed to verify impact on the dynamic performance of the system. As more accurate or unit specific dynamics data for the proposed facility, as well as Plant layout become available, it must be forwarded to PJM.

## **Retool Results**

This study evaluates the stability and low voltage ride-through (LVRT) capability for PJM queue project R49. The R49 project consists of 83 Vestas V100 1.8 MW wind turbines for a total of

149.4 MW. This wind farm will interconnect to the AEP system by tapping on the Havilland-Milan 138 kV line.

The stability and LVRT study for R49 was performed at 2013 summer peak conditions. The range of contingencies evaluated was limited to those necessary to assess compliance with the NERC criteria. Simulation time was 10 seconds for all faults.

This study includes 74 contingencies conditions that includes 3-phase permanent fault with unsuccessful High-Speed-Recloser (HSR) for normal clearing time contingencies and single line to ground for delayed clearing time due to stuck breaker condition and line tripping without fault.

Specific fault descriptions and breaker clearing times used for this study are provided in Appendix A. Generation equipment data is shown in Appendix B.

## Results

The R49 project was tested using the following conditions:

|                               | <b>R49</b> |
|-------------------------------|------------|
| Gross power output (MW)       | 149.4      |
| Reactive power output (MVARs) | 0          |
| Auxiliary load (MW/MVARs)     | 0          |
| Net real power injection      | 149.4      |

### All facilities in service:

1. Low Voltage Ride Through: For the cases studied, the R49 queue project rides through the faults shown in Appendix A thus meeting the LVRT test specified in FERC order 661 and 661A.
2. Voltage Recovery: For all cases studied, the R49 queue project recovers to an acceptable steady state voltage within 10 seconds.
3. Transient Stability: For all cases studied, transient stability is maintained with all oscillations stabilized in less than 10 seconds. Also, the voltage levels returned to normal for all cases following the fault clearance.

Maintenance outage: Maintenance outage conditions were not studied during the impact study phase since the project equipment data provided by the project developer is preliminary in nature. The stability and LVRT study including the maintenance outage test will be re-evaluated during the facility study phase (or at later stage), when more accurate dynamic data becomes available. Note that any and all changes to the generation equipment's dynamic data, including the GSU data, must be submitted to PJM for evaluation.

**Note:** While the stability analysis has been performed at extreme system conditions, there is a potential that evaluation at a different level of generator MW and/or MVAR output at different system load levels and operating conditions may disclose unforeseen stability problems. The regional reliability analysis routinely performed to test all system changes will include one such evaluation. Any problems uncovered in that or other operating or planning studies will need to be resolved.

Moreover, when the proposed generating station is designed and plant specific dynamic data for the plant and its controls are available, it must be forwarded to PJM. If it is different than the data provided for this study, a transient stability analysis at a variety of expected operating conditions using the more accurate data shall be performed to verify impact on the dynamic performance of the system. Note that any and all changes to the generation equipment's dynamic data, including the GSU data, must be submitted to PJM for evaluation.

### **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None

### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

### **Retool Result**

1. The overdutied condition of the E2 138kV circuit breaker at East Lima can be alleviated by replacing the circuit breaker with a 3000 A, 63 kA circuit breaker. The estimated time to replace is 14-18 months and cost for the circuit breaker replacement is \$278,450. (Network Upgrade #n1545)
2. The overdutied condition of the C 138kV circuit breaker at East Lima can be alleviated by replacing the circuit breaker with a 3000 A, 63 kA circuit breaker. The estimated time to replace is 14-18 months and cost for the circuit breaker replacement is \$278,450. (Network Upgrade #n1546)

### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*



None


### **Delivery of Energy Portion of Interconnection Request**

*(PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request. As a result of the aggregate energy resources in the area, the following violations were identified:)*


None

### **Cost Allocation**

The R49 project is responsible for 100% of the costs for the network upgrades listed under the Attachment Facilities section of the report estimated to cost **\$2,773,600**. The R49 project is also 100% responsible for the upgrade listed under Local Upgrades estimated to cost **\$1,856,600**.



**Exhibit 1: Approximate interconnection location of the proposed facilities.**



**Exhibit 2: Simplified diagram of proposed 138 kV in-line switching substation.**

**Attachment #1**  
**R49**  
2013 Light Load Stability Faults

**BREAKER CLEARING TIMES (CYCLES)**

| <u>Station</u> | <u>Primary (3ph/slg)</u> | <u>Stuck Breaker (total)</u> | <u>Line Open w/o Fault</u> |
|----------------|--------------------------|------------------------------|----------------------------|
| 345kV          | 4                        | 25                           |                            |
| 138kV          | 5                        | 20                           |                            |
| 69kV           | 63                       | 93                           |                            |
|                |                          |                              |                            |

**Table-1: Summary of the recommended maximum clearing time for the different case scenarios.**

**All cases stable**

- 1a. 3ph @ R49 – Milan 138 kV line  
1c. line-trip @ R49 – Milan 138 kV line

- 2a. 3ph @ Milan – Robison Park 138 kV line  
2b. slg @ Milan – Robison Park 138 kV line, BF @ Milan  
2c. line-trip @ Milan – Robison Park 138 kV line

- 3a. 3ph @ Robison Park – Lincoln 138 kV line 1  
3b. slg @ Robison Park – Lincoln 138 kV line 1, BF @ Robison Park  
Loss of: Robison\_Park-Guardian and Robison\_Park-Albion.  
3c. line-trip @ Robison Park – Lincoln 138 kV line 1

- 4a. 3ph @ Robison Park – Lincoln 138 kV line 2 through Reed  
4b. slg @ Robison Park – Lincoln 138 kV line 2 through Reed, BF @ Robison Park  
Loss of: Robison\_Park-Milan, Robison\_Park-Auburn, Robison\_Park-Lockwood.  
4c. line-trip @ Robison Park – Lincoln 138 kV line 2 through Reed

- 5a. 3ph @ Robison Park – Industrial Park 138 kV line through Summit  
5b. slg @ Robison Park – Industrial Park 138 kV line through Summit, BF @ Robison Park  
Loss of: Robison\_Park-Lincoln, Robison\_Park-Guardian, Robison\_Park-Albion  
5c. line-trip @ Robison Park – Industrial Park 138 kV line through Summit

- 6a. 3ph @ Robison Park – Albion 138 kV line through Huntertown  
6b. slg @ Robison Park – Albion 138 kV line through Huntertown, BF @ Robison Park  
Loss of: Robison\_Park-Lincoln, Robison\_Park-Guardian, Robison\_Park-Industrial Park  
6c. line-trip @ Robison Park – Albion 138 kV line through Huntertown

- 7a. 3ph @ Robison Park – Auburn 138 kV line through County  
7b. slg @ Robison Park – Auburn 138 kV line through County, BF @ Robison Park

Loss of: Robison\_Park-Milan, Robison Park-Lincoln\_2, Robison\_Park-Lockwood

7c. line-trip @ Robison Park – Auburn 138 kV line through County

---

8a. 3ph @ Robison Park – Lockwood 138 kV line through Grabill

8b. slg @ Robison Park – Lockwood 138 kV line through Grabill, BF @ Robison Park

Loss of: Robison\_Park-Milan, Robison Park-Lincoln\_2, Robison\_Park-Auburn

8c. line-trip @ Robison Park – Lockwood 138 kV line through Grabill

---

9a. 3ph @ R49 – Haviland 138 kV line

9c. line-trip @ R49 – Haviland 138 kV line

---

10a. 3ph @ Haviland - East Lima 138kV

10b. slg @ Haviland – East Lima 138 kV line, BF @ Haviland

Loss of: Haviland substation.

10c. line-trip @ Haviland – East Lima 138kV line,

---

11a. 3ph @ Haviland Transformer 138/69 kV line

---

12a. 3ph @ East Lima – West Lima 138 KV line

12b<sub>B</sub>. slg @ East Lima – West Lima 138 kV line, BF @ East Lima

Loss of: East Lima 345/138kV transformer (2A&2B).

12b<sub>B2</sub>. slg @ East Lima – West Lima 138 KV line, BF @ East Lima

Loss of: East Lima-Sterling.

12c. line-trip @ East Lima – West Lima 138 KV line

---

13a. 3ph @ East Lima – Thayer Road 138 KV line

13b<sub>E2</sub>. slg @ East Lima – Thayer Road 138 kV line, BF @ East Lima

Loss of: East Lima-East\_Leipsic.

13c. line-trip @ East Lima – Thayer Road 138 KV line

---

14a. 3ph @ East Lima – South Kenton 138 KV line

14b<sub>E1</sub>. slg @ East Lima – South Kenton 138 kV line, BF @ East Lima

14c. line-trip @ East Lima – South Kenton 138 KV line

---

15a. 3ph @ East Lima – RockHill 138 KV line

15b<sub>D</sub>. slg @ East Lima – RockHill 138 KV line, BF @ East Lima

Loss of: East Lima-Liberty

15b<sub>D2</sub>. slg @ East Lima – RockHill 138 KV line, BF @ East Lima

Loss of: East Lima-Sterling

15c. line-trip @ East Lima – RockHill 138 KV line

---

16a. 3ph @ East Lima – Ford Lima 138 KV line

16b<sub>C</sub>. slg @ East Lima – Ford Lima 138 KV line, BF @ East Lima

Loss of: East Lima 345/138kV transformer (1).

16b<sub>C2</sub>. slg @ East Lima – Ford Lima 138 KV line, BF @ East Lima

Loss of: East Lima-Sterling

16c. line-trip @ East Lima – Ford Lima 138 KV line

---

17a. 3ph @ East Lima – East Leipsic 138 KV line  
17c. line-trip @ East Lima – East Leipsic 138 KV line

---

18a. 3ph @ East Lima – North Findlay 138 KV line  
18b<sub>A</sub>. slg @ East Lima – North Findlay 138 KV line, BF @ East Lima  
**Loss of: East Lima-Haviland**  
18b<sub>A1</sub>. slg @ East Lima – North Findlay 138 KV line, BF @ East Lima  
**Loss of: East Lima-South Kenton**  
18c. line-trip @ East Lima – North Findlay 138 KV line

---

19a. 3ph @ East Lima – New Liberty 138 KV line,  
19b<sub>D</sub>. slg @ East Lima –New Liberty 138 KV line, BF @ East Lima  
**Loss of: East Lima-RockHill**  
19b<sub>D1</sub>. slg @ East Lima – New Liberty 138 KV line, BF @ East Lima  
**Loss of: East Lima-South Kenton**  
19c. line-trip @ East Lima – New Liberty 138 KV line

---

20a. 3ph @ East Lima – Fostoria Central 345 KV line  
20c. line-trip @ East Lima – Fostoria Central 345 KV line

---

21a. 3ph @ East Lima – South West Lima 345 KV line  
21c. line-trip @ East Lima – South West Lima 345 KV line

---

22a. 3ph @ East Lima – Marysville 345 KV line  
22c. line-trip @ East Lima – Marysville 345 KV line

---

23a. 3ph @ East Lima – R.P Mone 345 KV line  
23c. line-trip @ East Lima – Marysville 345 KV line

---

24a. 3ph @ Robison Park – Argent 345 kV line  
24c. line-trip @ Robison Park – Argent 345 kV line

---

25a. 3ph @ Robison Park – Collingwood 345 kV line  
25c. line-trip @ Robison Park – Collingwood 345 kV line

---

26a. 3ph @ Robison Park – Allen 345 kV line  
26c. line-trip @ Robison Park – Allen 345 kV line

---

27a. 3ph @ Robison Park – Convoy 345 kV line  
27c. line-trip @ Robison Park – Convoy 345 kV line

---

28a. 3ph @ Robison Park Transformer 345/138 kV

## APPENDIX A R49

### A.1) POWER FLOW CONDITIONS

2013 Summer Peak Base Case

### A.2) BREAKER CLEARING TIMES (CYCLES)

| <u>Station</u> | <u>Primary (3ph/slq)</u> | <u>Stuck Breaker (total)</u> | <u>Line Open w/o Fault</u> |
|----------------|--------------------------|------------------------------|----------------------------|
| 345kV          | 4                        | 25                           |                            |
| 138kV          | 5                        | 20                           |                            |
| 69kV           | 63                       | 93                           |                            |
|                |                          |                              |                            |

**Table-1: Summary of the recommended maximum clearing time for the different case scenarios.**

### A.3) FAULTS CONSIDERED (All facilities in service)

1a. 3ph @ R49 – Milan 138 kV line  
1c. line-trip @ R49 – Milan 138 kV line

2a. 3ph @ Milan – Robison Park 138 kV line  
2b. slg @ Milan – Robison Park 138 kV line, BF @ Milan  
2c. line-trip @ Milan – Robison Park 138 kV line

3a. 3ph @ Robison Park – Lincoln 138 kV line 1  
3b. slg @ Robison Park – Lincoln 138 kV line 1, BF @ Robison Park  
Loss of: Robison\_Park-Guardian and Robison\_Park-Albion.  
3c. line-trip @ Robison Park – Lincoln 138 kV line 1

4a. 3ph @ Robison Park – Lincoln 138 kV line 2 through Reed  
4b. slg @ Robison Park – Lincoln 138 kV line 2 through Reed, BF @ Robison Park  
Loss of: Robison\_Park-Milan, Robison\_Park-Auburn, Robison\_Park-Lockwood.  
4c. line-trip @ Robison Park – Lincoln 138 kV line 2 through Reed

5a. 3ph @ Robison Park – Industrial Park 138 kV line through Summit  
5b. slg @ Robison Park – Industrial Park 138 kV line through Summit, BF @ Robison Park  
Loss of: Robison\_Park-Lincoln, Robison\_Park-Guardian, Robison\_Park-Albion  
5c. line-trip @ Robison Park – Industrial Park 138 kV line through Summit

6a. 3ph @ Robison Park – Albion 138 kV line through Huntertown  
6b. slg @ Robison Park – Albion 138 kV line through Huntertown, BF @ Robison Park  
Loss of: Robison\_Park-Lincoln, Robison\_Park-Guardian, Robison\_Park-Industrial Park  
6c. line-trip @ Robison Park – Albion 138 kV line through Huntertown

---

7a. 3ph @ Robison Park – Auburn 138 kV line through County  
7b. slg @ Robison Park – Auburn 138 kV line through County, BF @ Robison Park  
Loss of: Robison\_Park-Milan, Robison Park-Lincoln\_2, Robison\_Park-Lockwood  
7c. line-trip @ Robison Park – Auburn 138 kV line through County

---

8a. 3ph @ Robison Park – Lockwood 138 kV line through Grabill  
8b. slg @ Robison Park – Lockwood 138 kV line through Grabill, BF @ Robison Park  
Loss of: Robison\_Park-Milan, Robison Park-Lincoln\_2, Robison\_Park-Auburn  
8c. line-trip @ Robison Park – Lockwood 138 kV line through Grabill

---

9a. 3ph @ R49 – Haviland 138 kV line  
9c. line-trip @ R49 – Haviland 138 kV line

---

10a. 3ph @ Haviland - East Lima 138kV  
10b. slg @ Haviland – East Lima 138 kV line, BF @ Haviland  
Loss of: Haviland substation.  
10c. line-trip @ Haviland – East Lima 138kV line,

---

11a. 3ph @ Haviland Transformer 138/69 kV line

---

12a. 3ph @ East Lima – West Lima 138 KV line  
12b<sub>B</sub>. slg @ East Lima – West Lima 138 kV line, BF @ East Lima  
Loss of: East Lima 345/138kV transformer (2A&2B).  
12b<sub>B2</sub>. slg @ East Lima – West Lima 138 KV line, BF @ East Lima  
Loss of: East Lima-Sterling.  
12c. line-trip @ East Lima – West Lima 138 KV line

---

13a. 3ph @ East Lima – Thayer Road 138 KV line  
13b<sub>E2</sub>. slg @ East Lima – Thayer Road 138 kV line, BF @ East Lima  
Loss of: East Lima-East\_Leipsic.  
13c. line-trip @ East Lima – Thayer Road 138 KV line

---

14a. 3ph @ East Lima – South Kenton 138 KV line  
14b<sub>E1</sub>. slg @ East Lima – South Kenton 138 kV line, BF @ East Lima  
14c. line-trip @ East Lima – South Kenton 138 KV line

---

15a. 3ph @ East Lima – RockHill 138 KV line  
15b<sub>D</sub>. slg @ East Lima – RockHill 138 KV line, BF @ East Lima  
Loss of: East Lima-Liberty  
15b<sub>D2</sub>. slg @ East Lima – RockHill 138 KV line, BF @ East Lima  
Loss of: East Lima-Sterling  
15c. line-trip @ East Lima – RockHill 138 KV line

---

16a. 3ph @ East Lima – Ford Lima 138 KV line  
16b<sub>C</sub>. slg @ East Lima – Ford Lima 138 KV line, BF @ East Lima  
Loss of: East Lima 345/138kV transformer (1).

16b<sub>C2</sub>. slg @ East Lima – Ford Lima 138 KV line, BF @ East Lima

Loss of: East Lima-Sterling

16c. line-trip @ East Lima – Ford Lima 138 KV line

---

17a. 3ph @ East Lima – East Leipsic 138 KV line

17c. line-trip @ East Lima – East Leipsic 138 KV line

---

18a. 3ph @ East Lima – North Findlay 138 KV line

18b<sub>A</sub>. slg @ East Lima – North Findlay 138 KV line, BF @ East Lima

Loss of: East Lima-Haviland

18b<sub>A1</sub>. slg @ East Lima – North Findlay 138 KV line, BF @ East Lima

Loss of: East Lima-South Kenton

18c. line-trip @ East Lima – North Findlay 138 KV line

---

19a. 3ph @ East Lima – New Liberty 138 KV line,

19b<sub>D</sub>. slg @ East Lima –New Liberty 138 KV line, BF @ East Lima

Loss of: East Lima-RockHill

19b<sub>D1</sub>. slg @ East Lima – New Liberty 138 KV line, BF @ East Lima

Loss of: East Lima-South Kenton

19c. line-trip @ East Lima – New Liberty 138 KV line

---

20a. 3ph @ East Lima – Fostoria Central 345 KV line

20c. line-trip @ East Lima – Fostoria Central 345 KV line

---

21a. 3ph @ East Lima – South West Lima 345 KV line

21c. line-trip @ East Lima – South West Lima 345 KV line

---

22a. 3ph @ East Lima – Marysville 345 KV line

22c. line-trip @ East Lima – Marysville 345 KV line

---

23a. 3ph @ East Lima – R.P Mone 345 KV line

23c. line-trip @ East Lima – Marysville 345 KV line

---

24a. 3ph @ Robison Park – Argent 345 kV line

24c. line-trip @ Robison Park – Argent 345 kV line

---

25a. 3ph @ Robison Park – Collingwood 345 kV line

25c. line-trip @ Robison Park – Collingwood 345 kV line

---

26a. 3ph @ Robison Park – Allen 345 kV line

26c. line-trip @ Robison Park – Allen 345 kV line

---

27a. 3ph @ Robison Park – Convoy 345 kV line

27c. line-trip @ Robison Park – Convoy 345 kV line


---



28a. 3ph @ Robison Park Transformer 345/138 kV

## Attachment #2

### Unit Capability Data



Net MW Capacity = (Gross MW Output - GSU MW Losses\* – Unit Auxiliary Load MW - Station Service Load MW)

Queue Letter/Position/Unit ID: \_\_\_\_\_ R49

Primary Fuel Type: \_\_\_\_\_ Wind /Suzlon S88 2.1 MW

Maximum Summer (92° F ambient air temp.) Net MW Output\*\*: \_\_\_\_ 151/2.1 per turbine

Maximum Summer (92° F ambient air temp.) Gross MW Output: \_\_\_\_ 151/2.1 per turbine

Minimum Summer (92° F ambient air temp.) Gross MW Output: \_\_\_\_\_ 0

Maximum Winter (30° F ambient air temp.) Gross MW Output: \_\_\_\_ 151/2.1 per turbine

Minimum Winter (30° F ambient air temp.) Gross MW Output: \_\_\_\_\_ 0

Gross Reactive Power Capability at Maximum Gross MW Output – Please include

Reactive Capability Curve (Leading and Lagging): \_\_\_\_\_ N/A

Individual Unit Auxiliary Load at Maximum Summer MW Output (MW/MVAR): \_N/A

Individual Unit Auxiliary Load at Minimum Summer MW Output (MW/MVAR): \_\_N/A

Individual Unit Auxiliary Load at Maximum Winter MW Output (MW/MVAR): \_\_\_\_N/A

Individual Unit Auxiliary Load at Minimum Winter MW Output (MW/MVAR): \_\_\_\_N/A

Station Service Load (MW/MVAR): \_\_\_\_\_ N/A

\* GSU losses are expected to be minimal.

\*\* Your project's declared MW, as first submitted in Attachment N, and later confirmed or modified by the Impact Study Agreement, should be based on either the 92° F Ambient Air Temperature rating of the unit(s) or, if less, the declared Capacity rating of your project.

### **Unit Generator Dynamics Data**

Queue Letter/Position/Unit ID: \_\_\_\_\_ R49

MVA Base (upon which all reactances, resistance and inertia are calculated): \_\_\_\_\_ 2.283

Nominal Power Factor: \_\_\_\_\_ N/A

Terminal Voltage (kV): \_\_\_\_\_ 0.6

#### Unsaturated Reactances (on MVA Base)

Direct Axis Synchronous Reactance,  $X_{d(i)}$ : \_\_\_\_\_ N/A

Direct Axis Transient Reactance,  $X'_{d(i)}$ : \_\_\_\_\_ N/A

Direct Axis Sub-transient Reactance,  $X''_{d(i)}$ : \_\_\_\_\_ N/A

Quadrature Axis Synchronous Reactance,  $X_{q(i)}$ : \_\_\_\_\_ N/A

Quadrature Axis Transient Reactance,  $X'_{q(i)}$ : \_\_\_\_\_ N/A

Quadrature Axis Sub-transient Reactance,  $X''_{q(i)}$ : \_\_\_\_\_ N/A

Stator Leakage Reactance,  $X_l$ : \_\_\_\_\_ N/A

Negative Sequence Reactance,  $X_{2(i)}$ : \_\_\_\_\_ N/A

Zero Sequence Reactance,  $X_0$ : \_\_\_\_\_ N/A

Saturated Sub-transient Reactance,  $X''_{d(v)}$  (on MVA Base): \_\_\_\_\_ N/A

Armature Resistance,  $R_a$  (on MVA Base): \_\_\_\_\_ N/A

#### Time Constants (seconds)

Direct Axis Transient Open Circuit,  $T'_{do}$ : \_\_\_\_\_ N/A

Direct Axis Sub-transient Open Circuit,  $T''_{do}$ : \_\_\_\_\_ N/A

Quadrature Axis Transient Open Circuit,  $T'_{qo}$ : \_\_\_\_\_ N/A

Quadrature Axis Sub-transient Open Circuit,  $T''_{qo}$ : \_\_\_\_\_ N/A

Inertia,  $H$  (kW-sec/kVA, on KVA Base): \_\_\_\_\_ N/A

Speed Damping,  $D$ : \_\_\_\_\_ N/A

Saturation Values at Per-Unit Voltage [ $S(1.0)$ ,  $S(1.2)$ ]: \_\_\_\_\_ N/A

*Units utilize a                      Generator model*

### **Unit GSU Data**

Queue Letter/Position/Unit ID: \_\_\_\_\_ R49 (72 GSU)  
Generator Step-up Transformer MVA Base: \_\_\_\_\_ 2.5  
Generator Step-up Transformer Impedance ( $R+jX$ , or %, on transformer MVA Base): \_ j0.0319  
Generator Step-up Transformer Reactance-to-Resistance Ration (X/R): \_\_\_\_\_ 10/1  
Generator Step-up Transformer Rating (MVA): \_\_\_\_\_ 2.5  
Generator Step-up Transformer Low-side Voltage (kV): \_\_\_\_\_ 0.6  
Generator Step-up Transformer High-side Voltage (kV): \_\_\_\_\_ 34.5  
Generator Step-up Transformer Off-nominal Turns Ratio: \_\_\_\_\_ N/A  
Generator Step-up Transformer Number of Taps and Step Size: \_\_\_\_\_ N/A

### **Main Transformer Data**


Queue Letter/Position/Unit ID: \_\_\_\_\_ R49 (1 Main Transformer)  
Generator Step-up Transformer MVA Base: \_\_\_\_\_ 100  
Generator Step-up Transformer Impedance ( $R+jX$ , or %, on transformer MVA Base): \_\_ 9.89%  
Generator Step-up Transformer Reactance-to-Resistance Ration (X/R): \_\_\_\_\_ 40/1  
Generator Step-up Transformer Rating (MVA): \_\_\_\_\_ 160  
Generator Step-up Transformer H-side Voltage (kV): \_\_\_\_\_ 138  
Generator Step-up Transformer X-side Voltage (kV): \_\_\_\_\_ 34.5  
Generator Step-up Transformer Off-nominal Turns Ratio: \_\_\_\_\_ N/A  
Generator Step-up Transformer Number of Taps and Step Size: \_\_\_\_\_ N/A

### Attachment #3

All the control systems were updated according to the developer's specification; these updates are shown in Dynamic Data Format.

**97689 'USRMDL' 1 'S88001' 1 1 11 79 4 32**  
**20 0 1 1 1 1 1 1 1 1 0.0053 0.1042 5.0556 0.0066 0.1097 2.8763 4.1622 5.6849**  
**71.3826 0.3 0.476 0.03 0.1697 0.0135 1.36 1.22 0.15 150.0 25.0 1850 150.0 25.0**  
**1820 37.0 -2.0 88.0 0.10 10.0 -10.0 18.0 1.225 9999 9999 0 9999 9999 0**  
**0.90 60.00 0.80 2.80 0.60 1.60 0.40 0.70 0.15 0.08 1.15 60.00 1.20 0.08 0.95 0.20**  
**1.05 0.20 0.90 1.10 0.00 1.00 0.00 1.00 0.10 1.00 0.20 1.00 0.30 1.00 0.40 1.00**  
**0.50 1.00 0.60 0.75 0.70 0.50 0.80 0.25 0.90 0.00 /R49\_Suzlon**

# Attachment #4



## APPENDIX B Project Data

### B.1) Wind farm and wind turbine data for R49

Queue Letter /Position/Unit ID: \_\_\_\_\_ R49

#### Wind farm data

Primary Fuel Type: \_\_\_\_\_ Wind

Maximum Net MW Output: \_\_\_\_\_ 149.4

Maximum Gross MW Output: \_\_\_\_\_ 149.4

Station Service Load in MW/MVAR: \_\_\_\_\_ N/A

#### Wind turbine data

Wind Turbine Type: \_\_\_\_\_ Vestas V100 1.8

MW Size: \_\_\_\_\_ 1.8

MVA Base: \_\_\_\_\_ 1.8

Nominal Power Factor: \_\_\_\_\_ N/A

Terminal Voltage (kV): \_\_\_\_\_ 0.69

Control Mode: \_\_\_\_\_

Number of Turbines (total): \_\_\_\_\_ 83

#### Wind farm capacitors

Queue Letter/Position/Unit ID: \_\_\_\_\_ R49

Additional Capacitor: \_\_\_\_\_ N/A

Location of Additional Capacitor: \_\_\_\_\_ N/A

Type of Additional Capacitor: \_\_\_\_\_ N/A

Steps of Switching Shunt: \_\_\_\_\_ N/A

#### Unit GSU data

Queue Letter /Position/Unit ID: \_\_\_\_\_ R49

Generator Step-up Transformer MVA Base: \_\_\_\_\_ 1.85

Generator Step-up Transformer Impedance ( $R+jX$ , on MVA Base): \_\_\_\_\_ 7.8%  
 Generator Step-up Transformer Reactance-to-Resistance Ratio ( $X/R$ ): \_\_\_\_\_ 10.4  
 Generator Step-up Transformer Rating (MVA): \_\_\_\_\_ 1.85  
 Generator Step-up Transformer Low-side Voltage (kV): \_\_\_\_\_ 0.69  
 Generator Step-up Transformer High-side Voltage (kV): \_\_\_\_\_ 34.5  
 Generator Step-up Transformer Off-nominal Turns Ratio: \_\_\_\_\_ N/A  
 Generator Step-up Transformer Number of Taps and Step Size: \_\_\_\_\_ N/A

### Main transformer data

Queue Letter /Position/Unit ID: \_\_\_\_\_ R49  
 Generator Step-up Transformer MVA Base: \_\_\_\_\_ 96  
 Generator Step-up Transformer Impedance ( $R+jX$ , in p.u, on Xfmr MVA Base): \_\_\_\_\_ 95%  
 Generator Step-up Transformer Reactance-to-Resistance Ration ( $X/R$ ): \_\_\_\_\_ 40  
 Generator Step-up Transformer Rating (MVA): \_\_\_\_\_ 160  
 Generator Step-up Transformer Low-side Voltage (kV): \_\_\_\_\_ 34.5  
 Generator Step-up Transformer High-side Voltage (kV): \_\_\_\_\_ 138  
 Generator Step-up Transformer Off-nominal Turns Ratio: \_\_\_\_\_ N/A

### Transmission line data:

Queue Letter/ ID: \_\_\_\_\_ R49  
 Transmission Line MVA Base: \_\_\_\_\_ N/A  
 Transmission Line kV Base: \_\_\_\_\_ N/A  
 Transmission Line length (mi): \_\_\_\_\_ N/A  
 Conductor Type: \_\_\_\_\_ N/A  
 Transmission Line Positive Seq. Impedance ( $R+jX$ , p.u. on **MVA Base**): \_\_\_\_\_ N/A  
 Transmission Line Positive Seq. Charging Admittance (B, p.u. on **MVA Base**): \_\_\_\_\_ N/A



## APPENDIX C PSSE MODEL

### C.1) Load flow model:

```

rdch
1
97686,'R49_COLL ', 34.5000,1, 0.000, 5.000, 205, 252,0.99225, -14.6625, 1
97689,'R49 ', 0.6000,2, 0.000, 0.000, 205, 252,0.99667, -10.3739, 1
0 / END OF BUS DATA, BEGIN LOAD DATA
0 / END OF LOAD DATA, BEGIN GENERATOR DATA
97689,'1 ', 149.400, 0.000, 0.000, 0.000,1.00000, 0, 149.400, 0.00000, 1.00000, 0.00000, 0.00000,1.00000,1, 100.0, 149.400,
0.000, 1,1.0000
0 / END OF GENERATOR DATA, BEGIN BRANCH DATA
0 / END OF BRANCH DATA, BEGIN TRANSFORMER DATA
97686, 23519, 0,'1 ',1,1,1, 0.00000, 0.00000,2,' ',1, 1,1.0000
0.00247, 0.09890, 100.00
1.00000, 0.000, 0.000, 160.00, 0.00, 0.00, 0, 0, 1.10000, 0.90000, 1.10000, 0.90000, 33, 0, 0.00000, 0.00000
1.00000, 0.000
97689, 97686, 0,'1 ',1,1,1, 0.00000, 0.00000,2,' ',1, 1,1.0000
0.00480, 0.04950, 100.00
1.00000, 0.000, 0.000, 157.70, 0.00, 0.00, 0, 0, 1.10000, 0.90000, 1.10000, 0.90000, 33, 0, 0.00000, 0.00000
1.00000, 0.000
0 / END OF TRANSFORMER DATA, BEGIN AREA DATA
205, 22987, 5711.000, 5.000,'AEP '
0 / END OF AREA DATA, BEGIN TWO-TERMINAL DC DATA
0 / END OF TWO-TERMINAL DC DATA, BEGIN VSC DC LINE DATA
0 / END OF VSC DC LINE DATA, BEGIN SWITCHED SHUNT DATA
0 / END OF SWITCHED SHUNT DATA, BEGIN IMPEDANCE CORRECTION DATA
0 / END OF IMPEDANCE CORRECTION DATA, BEGIN MULTI-TERMINAL DC DATA
0 / END OF MULTI-TERMINAL DC DATA, BEGIN MULTI-SECTION LINE DATA
0 / END OF MULTI-SECTION LINE DATA, BEGIN ZONE DATA
252,'AEP-IM '
0 / END OF ZONE DATA, BEGIN INTER-AREA TRANSFER DATA
0 / END OF INTER-AREA TRANSFER DATA, BEGIN OWNER DATA
1,'CENT HUD '
0 / END OF OWNER DATA, BEGIN FACTS DEVICE DATA
0 / END OF FACTS DEVICE DATA

```

## C.2) Dynamic model:

/ Vestas V90

```

97689 'USRMDL' 'I' 'VWCORE' 1 1 2 20 3 23 1 0
1800.0000 692.8203 899.6269 700.0000 2.6200 0.7620 0.0188
6.0050 8.3264 6.0050 8.3264 100.0000 0.4000 1.2000
0.1000 0.0000 0.0000 0.0000 0.0000 0.0000 /
0 'USRMDL' 0 'VWVARS' 8 0 2 0 0 18 97689 'I' /
0 'USRMDL' 0 'VWLVRT' 8 0 3 21 0 10 97689 'I' 1
0.85 0.001 0.2 12.5 50.0000 0.0000 0.0000
0.5 0.0000 2.6200 0.8079 1.2 0.5 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 /
0 'USRMDL' 0 'VWPWRC' 8 0 3 21 2 5 97689 'I' 0
1.0000 0.0000 0.0000 1.000 1.000 1.000 1.0000
1.0000 1.0000 1.0000 0.0000 0 0 0.1000
0.1000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 /
0 'USRMDL' 0 'VWMECH' 8 0 2 7 3 0 97689 'I'
1800.0000 351.8584 5684.1051 427.0000 65.0000 6358.0000 36.2900 /
0 'USRMDL' 0 'VWMEAS' 8 0 2 3 3 0 97689 'I'
0.1000 0.1000 0.2000 /
0 'USRMDL' 0 'VWVPRT' 0 2 7 20 0 11 97689 'I' 1 1 0 0 0
0.7500 0.0001 0.8500 0.4000 0.9000 60.0000 1.1000
60.0000 1.1350 0.2000 1.2000 0.0800 0.0000 0.2000
0.7000 2.6500 0.8000 11.0000 0.9000 60.0000 /
0 'USRMDL' 0 'VWFPRT' 0 2 3 4 0 1 97689 'I' 0
56.4000 0.2000 61.2000 0.2000 /

```

## C.3) Single-line diagram:




Figure C.1. Single-line diagram for R49. Breaker information not shown.

## C.4) Base Case Reinforcements:

None

***PJM Generator Interconnection Request  
Queue #R49  
Haviland-Milan(Ohio West Wind) 138kV  
Impact Study***

**539216  
June 2009**

## **R49 Haviland-Milan 138kV Impact Study Report**

### **General**

Horizon Wind Energy, LLC (Horizon) proposes to install a 150 MW generating facility comprised of 75-2.1 MW wind turbine generators connecting to the American Electric Power (AEP) Haviland - Milan 138 kV circuit. This project is number R49 in the PJM Generator Interconnection queue. The proposed location of the generating facilities and switching station is approximately four miles south of Payne, OH (See Exhibit 1). The projected in-service date is scheduled for October 31, 2010.

### **Attachment Facilities**

The proposed generation project will be connected to the AEP Haviland - Milan 138 kV circuit via a new in-line switching station. The new station will consist of three (3) 138 kV circuit breakers configured in a ring-bus arrangement with 138 kV metering (See Exhibit 2). AEP will retain ownership of the proposed in-line station facilities. In addition, remote terminal relaying will need to be upgraded to coordinate with the new relays to be installed at the new station. It is understood that Horizon will be responsible for the all costs associated with this construction, as well as facilities associated with connecting their 150 MW generation to the in-line facilities.

It is expected that any right-of-way for line extensions, as well as a 250' x 250' (minimum) station site will be provided to AEP by Horizon. Note that the Horizon station facilities and any facilities outside the new station were not included in the cost estimate. These are assumed to be Horizon's responsibility.

The AEP construction scope includes:

- Construction of a new switching station connecting to the Haviland - Milan 138 kV circuit between Haviland and Tillman stations, including three (3) 138 kV circuit breakers, relays, 138 kV metering, SCADA, and associated equipment. (Network Upgrade #n1222)

Estimated Cost (2009 Dollars): **\$4,485,300**

- Replace line relaying with AEP standard package and upgrade the station remote terminal unit (RTU) at Milan station. (Network Upgrade #n1223)

Estimated Cost (2009 Dollars): **\$682,500**

- Replace line relaying with AEP standard package and upgrade the station remote terminal unit (RTU) at Haviland station. (Network Upgrade #n1224)

Estimated Cost (2009 Dollars): **\$721,000**

- Replace line relaying with AEP standard package and upgrade the station remote terminal unit (RTU) at Tillman station. (Network Upgrade #n1225)

Estimated Cost (2009 Dollars): **\$370,100**

Total Attachment Facilities Cost\*: **\$6,258,900**

\*The estimates are preliminary in nature, as they were determined without the benefit of detailed engineering studies. Final estimates will require an on-site review and coordination to determine final construction requirements. It will take approximately fourteen (14) to eighteen (18) months after obtaining an executed ISA and CSA to construct the facilities as outlined above.

## **Local Impacts**

The impact of the proposed generating facility on the AEP System was assessed for adherence with applicable reliability criteria. AEP planning criteria require that the transmission system meet single contingency performance criteria in accordance with the AEP FERC Form 715. Therefore, this criterion was used to assess the impact of the proposed facility on the AEP System. The Horizon project was studied as a 150 MW net capacity consistent with the interconnection application. The results are summarized below.

### Normal System (2009 Summer Conditions)

- No problems identified.

### Single Contingency (2009 Summer Conditions)

- Outage of the Haviland - R49 Ohio West 138 kV circuit overloads the Tillman 138/34.5 kV transformer to 101% of its summer rating.

### Short Circuit Analysis

- No problems identified.

### Stability Analysis

- Instability occurs for an outage of the Robison Park - R49 and East Lima – Haviland 138 kV lines (double-contingency scenario). In this scenario, both 138 kV outlets are outaged, and R49 is connected only to the underlying 69 kV network via the Haviland

138/69 kV Station. **Generation curtailment will be required following the first contingency (loss of either the Robison Park – R49 or East Lima – Haviland 138 kV circuit).**

### **Local Upgrades**

To maintain appropriate levels of reliability and mitigate the single contingency problems resulting from the additional generation identified in this study, the following system improvements are required:

- To alleviate the overload on the Tillman 138/34.5kV transformer the existing transformer will be replaced with a 30 MVA unit that will require installation of a high-side circuit switcher and associated equipment. (Network Upgrade #n1226)

Estimated Cost (2009 Dollars): **\$1,856,600\***

\*The estimates are preliminary in nature, as they were determined without the benefit of detailed engineering studies. Final estimates will require an on-site review and coordination to determine final construction requirements. It will take approximately one year after obtaining the authorization to construct the facilities as outlined above.

### **Reactive Requirements**

PJM requires a power factor correction to 95% lead/lag at the point of interconnection for wind generating facilities. It is expected that Horizon will adhere to this standard.

### **Network Impacts**

The Queue Project #R49 was studied as a(n) 150 MW(Capacity=30 MW) injection into the Haviland – Milan 138 kV line in the AEP area. Project #R49 was evaluated for compliance with reliability criteria for summer peak conditions in 2012. Potential network impacts were as follows:

#### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

No problems were identified

#### **Multiple Facility Contingency**

*(Double Circuit Tower Line, Line with Failed Breaker and Bus Fault contingencies for the full energy output)*

No problems were identified

### **Short Circuit**

No problems identified

### **Stability and Reactive Power Requirement** **Background**

This study concerns the stability assessment for the PJM generator interconnection request – Queue #R49 (Havilland-Milan 138 kV Tap). The R49 project consists on a new 150 MW wind farm facility. The developer specified the use of 72 units Suzlon 2.1 MW wound rotor induction generator.

The objective of the study was to determine the system stability for the contingencies around the R49 project as shown in Attachment #1.

All units and its control systems were updated according to the developer's specification; these updates are shown in Attachment #2 and Attachment #3 (Dynamic data format).

The topology of the system is shown in Attachment #4

### **Stability (AEP Stability Criteria)**

Stability analysis was performed at 2013 summer peak load condition. The maximum generation output is considered. The range of contingencies evaluated was limited to that necessary to assess expected compliance with AEP criteria.

This study includes 74 contingencies conditions that includes 3-phase permanent fault with unsuccessful High-Speed-Recloser (HSR) for normal clearing time contingencies and single line to ground for delayed clearing time due to stuck breaker condition and line tripping without fault.

### **Result and Analysis**

No stability problem was identified with the new transmission line upgrade. The swing angles do not exceed the transient stability criteria and the transient voltage and low voltage ride through criteria were also satisfactory for all contingencies scenarios.

Table-1 in Attachment #1 tabulates the clearing times for the all contingencies scenarios, also a brief description of the scenario is provided.

Whenever R49 wind farm plant is islanded with a load, we recommend the following values for trip settings at the interconnection point:

Voltage at the point of interconnection:

0.8 pu or lower for 2 seconds

1.11 pu or higher for 0.1 second

1.2 pu or higher for 0.02 second

Frequency at the point of interconnection:

57Hz or lower for 0.05 seconds

62Hz or higher for 0.05 second

Note: While the stability analysis has been performed at expected extreme system conditions, there is a potential that evaluation at a different level of generator MW and/or MVAR output at different system load levels and operating conditions would disclose unforeseen stability problems. The regional reliability analysis routinely performed to test all system changes will include one such evaluation. Any problems uncovered in that or other operating or planning studies will need to be resolved.

Moreover, when the proposed generating station is designed and plant specific dynamics data for the plant and its controls are available, and if it is different than the data provided for this study, a transient stability analysis at a variety of expected operating conditions using the more accurate data shall be performed to verify impact on the dynamic performance of the system. As more accurate or unit specific dynamics data for the proposed facility, as well as Plant layout become available, it must be forwarded to PJM.

### **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None

### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None




### **Delivery of Energy Portion of Interconnection Request**

*(PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request. As a result of the aggregate energy resources in the area, the following violations were identified:)*


None

### **Cost Allocation**

The R49 project is responsible for 100% of the costs for the network upgrades listed under the Attachment Facilities section of the report estimated to cost **\$6,258,900**. The R49 project is also 100% responsible for the upgrade listed under Local Upgrades estimated to cost **\$1,856,600**.



**Exhibit 1: Approximate interconnection location of the proposed facilities.**



**Exhibit 2: Simplified diagram of proposed 138 kV in-line switching substation.**



**Attachment #1**  
**R49**  
2013 Light Load Stability Faults

**BREAKER CLEARING TIMES (CYCLES)**

| <u>Station</u> | <u>Primary (3ph/slg)</u> | <u>Stuck Breaker (total)</u> | <u>Line Open w/o Fault</u> |
|----------------|--------------------------|------------------------------|----------------------------|
| 345kV          | 4                        | 25                           |                            |
| 138kV          | 5                        | 20                           |                            |
| 69kV           | 63                       | 93                           |                            |
|                |                          |                              |                            |

**Table-1: Summary of the recommended maximum clearing time for the different case scenarios.**

**All cases stable**

1a. 3ph @ R49 – Milan 138 kV line  
1c. line-trip @ R49 – Milan 138 kV line

2a. 3ph @ Milan – Robison Park 138 kV line  
2b. slg @ Milan – Robison Park 138 kV line, BF @ Milan  
2c. line-trip @ Milan – Robison Park 138 kV line

3a. 3ph @ Robison Park – Lincoln 138 kV line 1  
3b. slg @ Robison Park – Lincoln 138 kV line 1, BF @ Robison Park  
Loss of: Robison\_Park-Guardian and Robison\_Park-Albion.  
3c. line-trip @ Robison Park – Lincoln 138 kV line 1

4a. 3ph @ Robison Park – Lincoln 138 kV line 2 through Reed  
4b. slg @ Robison Park – Lincoln 138 kV line 2 through Reed, BF @ Robison Park  
Loss of: Robison\_Park-Milan, Robison\_Park-Auburn, Robison\_Park-Lockwood.  
4c. line-trip @ Robison Park – Lincoln 138 kV line 2 through Reed

5a. 3ph @ Robison Park – Industrial Park 138 kV line through Summit  
5b. slg @ Robison Park – Industrial Park 138 kV line through Summit, BF @ Robison Park  
Loss of: Robison\_Park-Lincoln, Robison\_Park-Guardian, Robison\_Park-Albion  
5c. line-trip @ Robison Park – Industrial Park 138 kV line through Summit

6a. 3ph @ Robison Park – Albion 138 kV line through Huntertown  
6b. slg @ Robison Park – Albion 138 kV line through Huntertown, BF @ Robison Park  
Loss of: Robison\_Park-Lincoln, Robison\_Park-Guardian, Robison\_Park-Industrial Park  
6c. line-trip @ Robison Park – Albion 138 kV line through Huntertown

7a. 3ph @ Robison Park – Auburn 138 kV line through County  
7b. slg @ Robison Park – Auburn 138 kV line through County, BF @ Robison Park

Loss of: Robison\_Park-Milan, Robison Park-Lincoln\_2, Robison\_Park-Lockwood

7c. line-trip @ Robison Park – Auburn 138 kV line through County

---

8a. 3ph @ Robison Park – Lockwood 138 kV line through Grabill

8b. slg @ Robison Park – Lockwood 138 kV line through Grabill, BF @ Robison Park

Loss of: Robison\_Park-Milan, Robison Park-Lincoln\_2, Robison\_Park-Auburn

8c. line-trip @ Robison Park – Lockwood 138 kV line through Grabill

---

9a. 3ph @ R49 – Haviland 138 kV line

9c. line-trip @ R49 – Haviland 138 kV line

---

10a. 3ph @ Haviland - East Lima 138kV

10b. slg @ Haviland – East Lima 138 kV line, BF @ Haviland

Loss of: Haviland substation.

10c. line-trip @ Haviland – East Lima 138kV line,

---

11a. 3ph @ Haviland Transformer 138/69 kV line

---

12a. 3ph @ East Lima – West Lima 138 KV line

12b<sub>B</sub>. slg @ East Lima – West Lima 138 kV line, BF @ East Lima

Loss of: East Lima 345/138kV transformer (2A&2B).

12b<sub>B2</sub>. slg @ East Lima – West Lima 138 KV line, BF @ East Lima

Loss of: East Lima-Sterling.

12c. line-trip @ East Lima – West Lima 138 KV line

---

13a. 3ph @ East Lima – Thayer Road 138 KV line

13b<sub>E2</sub>. slg @ East Lima – Thayer Road 138 kV line, BF @ East Lima

Loss of: East Lima-East\_Leipsic.

13c. line-trip @ East Lima – Thayer Road 138 KV line

---

14a. 3ph @ East Lima – South Kenton 138 KV line

14b<sub>E1</sub>. slg @ East Lima – South Kenton 138 kV line, BF @ East Lima

14c. line-trip @ East Lima – South Kenton 138 KV line

---

15a. 3ph @ East Lima – RockHill 138 KV line

15b<sub>D</sub>. slg @ East Lima – RockHill 138 KV line, BF @ East Lima

Loss of: East Lima-Liberty

15b<sub>D2</sub>. slg @ East Lima – RockHill 138 KV line, BF @ East Lima

Loss of: East Lima-Sterling

15c. line-trip @ East Lima – RockHill 138 KV line

---

16a. 3ph @ East Lima – Ford Lima 138 KV line

16b<sub>C</sub>. slg @ East Lima – Ford Lima 138 KV line, BF @ East Lima

Loss of: East Lima 345/138kV transformer (1).

16b<sub>C2</sub>. slg @ East Lima – Ford Lima 138 KV line, BF @ East Lima

Loss of: East Lima-Sterling

16c. line-trip @ East Lima – Ford Lima 138 KV line

---

17a. 3ph @ East Lima – East Leipsic 138 KV line  
17c. line-trip @ East Lima – East Leipsic 138 KV line

---

18a. 3ph @ East Lima – North Findlay 138 KV line  
18b<sub>A</sub>. slg @ East Lima – North Findlay 138 KV line, BF @ East Lima  
Loss of: East Lima-Haviland  
18b<sub>A1</sub>. slg @ East Lima – North Findlay 138 KV line, BF @ East Lima  
Loss of: East Lima-South Kenton  
18c. line-trip @ East Lima – North Findlay 138 KV line

---

19a. 3ph @ East Lima – New Liberty 138 KV line,  
19b<sub>D</sub>. slg @ East Lima – New Liberty 138 KV line, BF @ East Lima  
Loss of: East Lima-RockHill  
19b<sub>D1</sub>. slg @ East Lima – New Liberty 138 KV line, BF @ East Lima  
Loss of: East Lima-South Kenton  
19c. line-trip @ East Lima – New Liberty 138 KV line

---

20a. 3ph @ East Lima – Fostoria Central 345 KV line  
20c. line-trip @ East Lima – Fostoria Central 345 KV line

---

21a. 3ph @ East Lima – South West Lima 345 KV line  
21c. line-trip @ East Lima – South West Lima 345 KV line

---

22a. 3ph @ East Lima – Marysville 345 KV line  
22c. line-trip @ East Lima – Marysville 345 KV line

---

23a. 3ph @ East Lima – R.P Mone 345 KV line  
23c. line-trip @ East Lima – Marysville 345 KV line

---

24a. 3ph @ Robison Park – Argent 345 kV line  
24c. line-trip @ Robison Park – Argent 345 kV line

---

25a. 3ph @ Robison Park – Collingwood 345 kV line  
25c. line-trip @ Robison Park – Collingwood 345 kV line

---

26a. 3ph @ Robison Park – Allen 345 kV line  
26c. line-trip @ Robison Park – Allen 345 kV line

---


27a. 3ph @ Robison Park – Convoy 345 kV line  
27c. line-trip @ Robison Park – Convoy 345 kV line

---

28a. 3ph @ Robison Park Transformer 345/138 kV

## Attachment #2

### Unit Capability Data



Net MW Capacity = (Gross MW Output - GSU MW Losses\* – Unit Auxiliary Load MW - Station Service Load MW)

Queue Letter/Position/Unit ID: \_\_\_\_\_ R49

Primary Fuel Type: \_\_\_\_\_ Wind /Suzlon S88 2.1 MW

Maximum Summer (92° F ambient air temp.) Net MW Output\*\*: \_\_\_\_ 151/2.1 per turbine

Maximum Summer (92° F ambient air temp.) Gross MW Output: \_\_\_\_ 151/2.1 per turbine

Minimum Summer (92° F ambient air temp.) Gross MW Output: \_\_\_\_\_ 0

Maximum Winter (30° F ambient air temp.) Gross MW Output: \_\_\_\_ 151/2.1 per turbine

Minimum Winter (30° F ambient air temp.) Gross MW Output: \_\_\_\_\_ 0

Gross Reactive Power Capability at Maximum Gross MW Output – Please include

Reactive Capability Curve (Leading and Lagging): \_\_\_\_\_ N/A

Individual Unit Auxiliary Load at Maximum Summer MW Output (MW/MVAR): \_N/A

Individual Unit Auxiliary Load at Minimum Summer MW Output (MW/MVAR): \_\_N/A

Individual Unit Auxiliary Load at Maximum Winter MW Output (MW/MVAR): \_\_\_\_N/A

Individual Unit Auxiliary Load at Minimum Winter MW Output (MW/MVAR): \_\_\_\_N/A

Station Service Load (MW/MVAR): \_\_\_\_\_ N/A

\* GSU losses are expected to be minimal.

\*\* Your project's declared MW, as first submitted in Attachment N, and later confirmed or modified by the Impact Study Agreement, should be based on either the 92° F Ambient Air Temperature rating of the unit(s) or, if less, the declared Capacity rating of your project.

### Unit Generator Dynamics Data

Queue Letter/Position/Unit ID: \_\_\_\_\_ R49

MVA Base (upon which all reactances, resistance and inertia are calculated): \_\_\_\_\_ 2.283

Nominal Power Factor: \_\_\_\_\_ N/A

Terminal Voltage (kV): \_\_\_\_\_ 0.6

#### Unsaturated Reactances (on MVA Base)

Direct Axis Synchronous Reactance,  $X_{d(i)}$ : \_\_\_\_\_ N/A

Direct Axis Transient Reactance,  $X'_{d(i)}$ : \_\_\_\_\_ N/A

Direct Axis Sub-transient Reactance,  $X''_{d(i)}$ : \_\_\_\_\_ N/A

Quadrature Axis Synchronous Reactance,  $X_{q(i)}$ : \_\_\_\_\_ N/A

Quadrature Axis Transient Reactance,  $X'_{q(i)}$ : \_\_\_\_\_ N/A

Quadrature Axis Sub-transient Reactance,  $X''_{q(i)}$ : \_\_\_\_\_ N/A

Stator Leakage Reactance,  $X_l$ : \_\_\_\_\_ N/A

Negative Sequence Reactance,  $X_{2(i)}$ : \_\_\_\_\_ N/A

Zero Sequence Reactance,  $X_0$ : \_\_\_\_\_ N/A

Saturated Sub-transient Reactance,  $X''_{d(v)}$  (on MVA Base): \_\_\_\_\_ N/A

Armature Resistance,  $R_a$  (on MVA Base): \_\_\_\_\_ N/A

#### Time Constants (seconds)

Direct Axis Transient Open Circuit,  $T'_{do}$ : \_\_\_\_\_ N/A

Direct Axis Sub-transient Open Circuit,  $T''_{do}$ : \_\_\_\_\_ N/A

Quadrature Axis Transient Open Circuit,  $T'_{qo}$ : \_\_\_\_\_ N/A

Quadrature Axis Sub-transient Open Circuit,  $T''_{qo}$ : \_\_\_\_\_ N/A

Inertia,  $H$  (kW-sec/kVA, on KVA Base): \_\_\_\_\_ N/A

Speed Damping,  $D$ : \_\_\_\_\_ N/A

Saturation Values at Per-Unit Voltage [ $S(1.0)$ ,  $S(1.2)$ ]: \_\_\_\_\_ N/A

*Units utilize a Generator model*



### **Unit GSU Data**

Queue Letter/Position/Unit ID: \_\_\_\_\_ R49 (72 GSU)  
Generator Step-up Transformer MVA Base: \_\_\_\_\_ 2.5  
Generator Step-up Transformer Impedance ( $R+jX$ , or %, on transformer MVA Base): \_  $j0.0319$   
Generator Step-up Transformer Reactance-to-Resistance Ration (X/R): \_\_\_\_\_ 10/1  
Generator Step-up Transformer Rating (MVA): \_\_\_\_\_ 2.5  
Generator Step-up Transformer Low-side Voltage (kV): \_\_\_\_\_ 0.6  
Generator Step-up Transformer High-side Voltage (kV): \_\_\_\_\_ 34.5  
Generator Step-up Transformer Off-nominal Turns Ratio: \_\_\_\_\_ N/A  
Generator Step-up Transformer Number of Taps and Step Size: \_\_\_\_\_ N/A

### **Main Transformer Data**

Queue Letter/Position/Unit ID: \_\_\_\_\_ R49 (1 Main Transformer)  
Generator Step-up Transformer MVA Base: \_\_\_\_\_ 100  
Generator Step-up Transformer Impedance ( $R+jX$ , or %, on transformer MVA Base): \_\_ 9.89%  
Generator Step-up Transformer Reactance-to-Resistance Ration (X/R): \_\_\_\_\_ 40/1  
Generator Step-up Transformer Rating (MVA): \_\_\_\_\_ 160  
Generator Step-up Transformer H-side Voltage (kV): \_\_\_\_\_ 138  
Generator Step-up Transformer X-side Voltage (kV): \_\_\_\_\_ 34.5  
Generator Step-up Transformer Off-nominal Turns Ratio: \_\_\_\_\_ N/A  
Generator Step-up Transformer Number of Taps and Step Size: \_\_\_\_\_ N/A

### **Attachment #3**

All the control systems were updated according to the developer's specification; these updates are shown in Dynamic Data Format.

**97689 'USRMDL' 1 'S88001' 1 1 11 79 4 32  
20 0 1 1 1 1 1 1 1 1 0.0053 0.1042 5.0556 0.0066 0.1097 2.8763 4.1622 5.6849  
71.3826 0.3 0.476 0.03 0.1697 0.0135 1.36 1.22 0.15 150.0 25.0 1850 150.0 25.0  
1820 37.0 -2.0 88.0 0.10 10.0 -10.0 18.0 1.225 9999 9999 0 9999 9999 0  
0.90 60.00 0.80 2.80 0.60 1.60 0.40 0.70 0.15 0.08 1.15 60.00 1.20 0.08 0.95 0.20  
1.05 0.20 0.90 1.10 0.00 1.00 0.00 1.00 0.10 1.00 0.20 1.00 0.30 1.00 0.40 1.00  
0.50 1.00 0.60 0.75 0.70 0.50 0.80 0.25 0.90 0.00 /R49\_Suzlon**

# Attachment #4

